

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
County: <u>Wyandott</u>		<u>NE 1/4 SW 1/4 SE 1/4</u>	<u>15</u>	T <u>11</u> S	R <u>24</u> <u>EN</u>
Distance and direction from nearest town or city street address of well if located within city? <u>530 S. 65th STREET, Kansas City, KS</u>					
2 WATER WELL OWNER:		Board of Agriculture, Division of Water Resources			
RR#, St. Address, Box #		Application Number:			
City, State, ZIP Code					
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: <u>99.70</u> ft. ELEVATION: <u>768.60</u>			
		Depth(s) Groundwater Encountered 1. <u>37.49</u> ft. 2. ft. 3. ft.			
		WELL'S STATIC WATER LEVEL <u>39.42</u> ft. below land surface measured on mo/day/yr			
		Pump test data: Well water was ft. after hours pumping gpm			
		Est. Yield gpm: Well water was ft. after hours pumping gpm			
		Bore Hole Diameter <u>8.25</u> in. to <u>49.70</u> ft., and in. to ft.			
		WELL WATER TO BE USED AS:			
		5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only <u>10</u> Monitoring well			
		Was a chemical/bacteriological sample submitted to Department? Yes.....No <u>X</u>; If yes, mo/day/yr sample was sub- mitted			
		Water Well Disinfected? Yes No <u>X</u>			
5 TYPE OF BLANK CASING USED:					
1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped <u>2</u> PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded Blank casing diameter <u>2</u> in. to <u>34.70</u> ft., Dia. in. to ft., Dia. in. to ft. Casing height above land surface <u>3</u> in., weight lbs./ft. Wall thickness or gauge No. <u>40</u>					
TYPE OF SCREEN OR PERFORATION MATERIAL:					
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify) SCREEN OR PERFORATION OPENINGS ARE: 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 1 Continuous slot <u>3</u> Mill slot 6 Wire wrapped 9 Drilled holes 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)					
SCREEN-PERFORATED INTERVALS: From <u>49.70</u> ft. to <u>59.70</u> ft., From ft. to ft.					
GRAVEL PACK INTERVALS: From ft. to ft., From ft. to ft.					
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout <u>3</u> Bentonite 4 Other					
Grout Intervals: From <u>34.70</u> ft. to <u>1</u> ft., From ft. to ft., From ft. to ft.					
What is the nearest source of possible contamination:					
1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) 13 Insecticide storage					
Direction from well? How many feet?					
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
<u>0</u>	<u>10</u>	<u>Asphalt</u>	<u>50</u>	<u>33</u>	<u>Filter pack sand</u>
<u>1</u>	<u>10</u>	<u>Silty clay</u>	<u>33</u>	<u>31</u>	<u>hydrated bentonite chips</u>
<u>10</u>	<u>36.5</u>	<u>Silt</u>	<u>31</u>	<u>1</u>	<u>bentonite grout</u>
<u>36.5</u>	<u>50</u>	<u>Fine-grained sand</u>	<u>1</u>	<u>0</u>	<u>concrete</u>
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <u>(1)</u> constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>5/31/07</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>749</u> This Water Well Record was completed on (mo/day/yr) <u>7/20/07</u> under the business name of <u>TERRANEXT</u> by (signature) <u>Frank Smith</u>					