


1 LOCATION OF WATER WELL: County: <u>Wyandotte</u>		Fraction <u>NE</u> $\frac{1}{4}$ <u>SW</u> $\frac{1}{4}$ <u>NE</u> $\frac{1}{4}$	Section Number <u>12</u>	Township Number T <u>11</u> S	Range Number R <u>24</u> E																																																						
Distance and direction from nearest town or city street address of well if located within city? <u>4800 Kaw Drive Forest View P-7</u>																																																											
2 WATER WELL OWNER: <u>Waste Management</u> RR#, St. Address, Box #: <u>4800 Kaw Drive</u> City, State, ZIP Code: <u>PO Box 11116 KCK 66111</u>			Board of Agriculture, Division of Water Resources Application Number:																																																								
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: 		4 DEPTH OF COMPLETED WELL: <u>150</u> ft. ELEVATION: <u>975.8</u> Depth(s) Groundwater Encountered 1. <u>75</u> ft. 2. ft. 3. ft. WELL'S STATIC WATER LEVEL ft. below land surface measured on mo/day/yr Pump test data: Well water was ft. after hours pumping gpm Est. Yield gpm: Well water was ft. after hours pumping gpm Bore Hole Diameter: <u>5 7/8</u> in. to <u>110</u> ft. and <u>3 7/8</u> in. to <u>150</u> ft. WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only <u>10 Observation well</u> Was a chemical/bacteriological sample submitted to Department? Yes No <u>X</u> ; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes No <u>X</u>																																																									
5 TYPE OF BLANK CASING USED: 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped <u>2 PVC</u> 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded Blank casing diameter <u>2</u> in. to <u>138.4</u> ft. Dia. in. to ft. Dia. in. to ft. Casing height above land surface <u>30</u> in., weight lbs./ft. Wall thickness or gauge No. <u>sch 40</u> TYPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify) 12 None used (open hole) SCREEN OR PERFORATION OPENINGS ARE: 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes 10 Other (specify) SCREEN-PERFORATED INTERVALS: From <u>138.4</u> ft. to <u>148.4</u> ft. From ft. to ft. From ft. to ft. From ft. to ft. GRAVEL PACK INTERVALS: From <u>135.0</u> ft. to <u>150.0</u> ft. From ft. to ft. From ft. to ft. From ft. to ft.																																																											
6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other Grout Intervals: From <u>0</u> ft. to <u>132</u> ft. From <u>132</u> ft. to <u>135</u> ft. From ft. to ft. What is the nearest source of possible contamination: 1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) 13 Insecticide storage <u>Land fill</u> Direction from well? How many feet? <u>100</u>																																																											
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>FROM</th> <th>TO</th> <th>LITHOLOGIC LOG</th> <th>FROM</th> <th>TO</th> <th>LITHOLOGIC LOG</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>72</td> <td>brown silty clays</td> <td>147</td> <td>150</td> <td>grey shale</td> </tr> <tr> <td>72</td> <td>97</td> <td>brown white LS</td> <td></td> <td></td> <td></td> </tr> <tr> <td>97</td> <td>98</td> <td>grey shale</td> <td></td> <td></td> <td></td> </tr> <tr> <td>98</td> <td>103</td> <td>grey white L.S.</td> <td></td> <td></td> <td></td> </tr> <tr> <td>103</td> <td>137.5</td> <td>grey shale</td> <td></td> <td></td> <td></td> </tr> <tr> <td>137.5</td> <td>143</td> <td>grey white LS</td> <td></td> <td></td> <td></td> </tr> <tr> <td>143</td> <td>145</td> <td>drk grey to black shale</td> <td></td> <td></td> <td></td> </tr> <tr> <td>145</td> <td>147</td> <td>grey white L.S.</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>						FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG	0	72	brown silty clays	147	150	grey shale	72	97	brown white LS				97	98	grey shale				98	103	grey white L.S.				103	137.5	grey shale				137.5	143	grey white LS				143	145	drk grey to black shale				145	147	grey white L.S.			
FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG																																																						
0	72	brown silty clays	147	150	grey shale																																																						
72	97	brown white LS																																																									
97	98	grey shale																																																									
98	103	grey white L.S.																																																									
103	137.5	grey shale																																																									
137.5	143	grey white LS																																																									
143	145	drk grey to black shale																																																									
145	147	grey white L.S.																																																									
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>2-28-90</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>438</u> This Water Well Record was completed on (mo/day/yr) <u>5-14-90</u> under the business name of <u>Kansas City Testing Lab</u> by (signature) <u>Richard C. Leeds</u>																																																											
INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Bureau of Water Protection, Topeka, Kansas 66620-7320, Telephone: 913-862-9360. Send one to WATER WELL OWNER and retain one for your records.																																																											

OFFICE USE ONLY

T

R

EW

SEC.

1/4

1/4

1/4