

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County WYANDOTTE	Township name DELEWARE	Fraction SW NE/NE	Section number 15	Town number 115	Range number 25E
Distance and direction from nearest town or city: KANSAS CITY, KANSAS				3 Owner of well: CORP OF ENGINEERS		
Street address of well location if in city: WELL NO. 11 SYSTEM II 3RD & BUNKER				Address: KANSAS CITY, MISSOURI		
Locate with "X" in section below: N W E S 1 Mile		Sketch map: RR KANSAS RIVER		4 Well depth: 62 ft. Date of completion 5-21-75 Well diameter 30 in.		
2 Type and color of material From To SILT CINDERS BRICK SILT (BROWN) FINE TO MEDIUM SAND (GRAY) CLAY (GRAY) FINE SAND (GRAY) CLAY SAND w/CLAY SHEETS (GRAY)				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> RELIEF		
				7 Casing: Material FBGLS Height: above /below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> in. Diam. <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. 12 in. to 61 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth		
				8 Screen: Manufacturer FIBERGLASS RESOURCES Type SLOTTED Dia. 12 Slot/gauze 1/16 Length 15 Set between 54 ft. and 28 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4		
				9 Static water level: 23 ft. below land surface Date 9-2-75		
				10 Pumping level below land surfaces: 29.5 ft. after 4 hrs. pumping 140 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 100 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				12 Well head completion: No <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> CONCRETE Depth: From 23 ft. to 4 ft.		
				14 Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
(use a second sheet if needed)				15 Pump: NONE <input type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				16 Remarks: elevation 740 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. LAYNE - WESTERN CO. 149 Business name License No. Address 1010 W. 37th Signed C. Allen Date 6/1/75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5