



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Wyandotte	Township name Delaware	Fraction NE SW	Section number 22	Town number 11S	Range number 25E		
Distance and direction from nearest town or city: Kansas City, KS			3 Owner of well: Corp of Engineers					
Street address of well location if in city: 2 System I Packard & Lucille			Address: Kansas City, Missouri					
Locate with "X" in section below: N  W E S 1 Mile			Sketch map: MIDWEST COLD STORAGE  KANSAS RIVER N			4 Well depth: 94 ft. Date of completion: 10/31/74 Well diameter 30 in.		
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			Fine sand (brown) fill		0	14	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> Relief	
			Clay, gray		14	31	7 Casing: Material Fiberglass Height: above /below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 10' in. Diam. 12 in. to 93 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth	
			Medium sand, (brown)		31	64	8 Screen: Manufacturer Fiberglass Resource Type Slotted Dia. 12" Slot/gauze 1/16" Length 36' Set between 93 ft. and 43 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2"	
Coarse sand, (brown)			64	94	9 Static water level: 36 ft. below land surface Date 7/14/75			
					10 Pumping level below land surfaces: 42 ft. after 4 hrs. pumping 690 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 600 g.p.m.			
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____			
					12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade			
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Concrete <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite Depth: From 39 ft. to 19 ft.			
					14 Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
					15 Pump: None <input type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(use a second sheet if needed)								
16 Remarks: elevation 762 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co 149 Business name _____ License No. _____ Address 1010 W 39th St KE MO Signed C. Allen Date 10/31/74 Authorized representative					