

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Jearny	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 10	Township number T 11 S	Range number R 5 EAST E/W
2. Distance and direction from nearest town or city 4 miles north west of Junction City			3. Owner of well: Sgt Stephen Cochrell			
Street address of well location if in city:			R.R. or street: 4648-8 Lee St			
			City, state, zip code: Fort Riley Kans 66442			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 11 in. Completion date		
				Well depth 130 ft. 4-29-78		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
7 of Soil, Black		0	2	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 130 ft. depth Wall Thickness: inches Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 267 wall		
Rock, loose limestone, yellow		2	3	10. Screen: Manufacturer's name Type P.V.C Dia. 5 Slot/gauge 130 Length 70 Set between 130 ft. and 90 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 X 1/4		
clay, yellow		3	18	11. Static water level: 90 ft. below land surface Date 4-29-78		
Rock, Hard Limestone, yellow		18	28	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 30 g.p.m.		
clay, Red		28	60	13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date		
Rock Hard chalk, white		60	65	14. Well head completion: NA <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
clay, yellow		65	88	15. Well grouted? <input checked="" type="checkbox"/> 1-2 With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 15 ft. to 5 ft.		
Rock, yellow limestone, water		88	105	16. Nearest source of possible contamination: ft. 150 Direction West Type Lateral Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
shale, blue		105	130	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Drilling Co. 237 Business name Blue R aptls NS License No. _____ Address _____ Signed Harold Strader Date 4-30-78 Authorized representative		
18. Elevation:	19. Remarks:		20. Water well contractor's certification:			
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

11-50-10
R 50 W 10
NE 8-11-11