

mit Forb Corps.

to BWS, 10-9-88

1 LOCATION OF WATER WELL  
 County: Geary Fraction NW 1/4 NW 1/4 NW 1/4 Section Number 28 Township Number T 11 S Range Number R 5 E

Distance and direction from nearest town or city? 1 1/2 W + 1 N. Junction City, Ks. Street address of well if located within city?

2 WATER WELL OWNER: DEPARTMENT OF ARMY KANSAS CITY DISTRICT, Corps of Engineers  
 RR#, St. Address, Box #: 700 FEDERAL Bldg - K.C. Mo. 64106  
 City, State, ZIP Code: 700 FEDERAL Bldg - K.C. Mo. 64106  
 Board of Agriculture, Division of Water Resources Application Number:

3 DEPTH OF COMPLETED WELL: 39 ft. Bore Hole Diameter: 12 in. to 20 ft., and 8 in. to 20-39 ft.  
 Well Water to be used as:  
 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well  
 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)  
 7 Lawn and garden only 10 Observation well  
 Well's static water level: 25 ft. below land surface measured on AUGUST month 25 day 1980 year  
 Pump Test Data: Well water was 100 gpm: Well water was 100 gpm: Well water was 100 gpm: Well water was 100 gpm:  
 Est. Yield 100 gpm: Well water was 100 gpm: Well water was 100 gpm: Well water was 100 gpm:

4 TYPE OF BLANK CASING USED:  
 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped  
 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded Threaded  
 7 Fiberglass  
 Blank casing dia: 6 in. to 0-32 ft., Dia: 6 in. to 0-32 ft., Dia: 6 in. to 0-32 ft., Dia: 6 in. to 0-32 ft.  
 Casing height above land surface: 36 in., weight: 18.97 lbs./ft. Wall thickness or gauge No: 280  
 TYPE OF SCREEN OR PERFORATION MATERIAL:  
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement  
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify)  
 12 None used (open hole)  
 Screen or Perforation Openings Are: JOHNSON 40 SLOT 5 Gauzed wrapped 8 Saw cut 11 None (open hole)  
 1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes  
 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)  
 Screen-Perforation Dia: 6 in. to 6 in. to 6 in. to 6 in. to 6 in. to 6 in. to  
 Screen-Perforated Intervals: From 32 ft. to 39 ft., From 32 ft. to 39 ft., From 32 ft. to 39 ft., From 32 ft. to 39 ft., From 32 ft. to 39 ft., From 32 ft. to 39 ft.  
 Gravel Pack Intervals: From 20 ft. to 39 ft., From 20 ft. to 39 ft., From 20 ft. to 39 ft., From 20 ft. to 39 ft., From 20 ft. to 39 ft., From 20 ft. to 39 ft.

5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other  
 Grouted Intervals: From 0 ft. to 30 ft., From 0 ft. to 30 ft., From 0 ft. to 30 ft., From 0 ft. to 30 ft., From 0 ft. to 30 ft., From 0 ft. to 30 ft.  
 What is the nearest source of possible contamination:  
 1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well  
 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well  
 3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)  
 13 Watertight sewer lines  
 Direction from well: W How many feet: 350 ? Water Well Disinfected? Yes ✓ No  
 Was a chemical/bacteriological sample submitted to Department? Yes ✓ No ✗ If yes, date sample was submitted: SEPT month 17 day 1980 year: Pump Installed? Yes ✓ No  
 If Yes: Pump Manufacturer's name: Jacuzzi Model No: 254D HP: 2 Volts: 230  
 Depth of Pump Intake: 35 ft. Pumps Capacity rated at: 30 gal./min.  
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed (2) reconstructed, or (3) plugged under my jurisdiction and was completed on September month 24 day 1980 year  
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 182  
 This Water Well Record was completed on September month 24 day 1980 year under the business name of STRADER DRILLING Co Inc by (signature) Dale Babren

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM		TO		LITHOLOGIC LOG		FROM		TO		LITHOLOGIC LOG	
	0	6	TOP SOIL									
	6	16	FINE SAND, SILT									
	16	25	FINE SAND, COURSE SAND, med GRAVEL									
	25	39	"	"	"	"	"	"	"	"	"	PRAGRAVEL
	39	40	SHALY, grey									

ELEVATION:  
 Depth(s) Groundwater Encountered 1. 20 ft. 2. 20 ft. 3. 20 ft. 4. 20 ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.