

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

114
 home
 call again

WATER WELL RECORD
 KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
 (Water well Contractors)
 Topeka, Kansas 66620

Riley Co? NE-NE-NE? 11?

1. Location of well:	County WABAUNSEE	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 2	Township number T 11	Range number S R 9 E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:	3 E 1 W 3 S 430 F OF ZEANDALE		3. Owner of well: R. or street: City, state, zip code:	Talley - Dwayne GEN RESEARCH DR MANHATTAN, KS 66502	
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 8 in. Completion date Well depth 100 ft. 9-17-76	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material	From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
TOP SOIL	0	3	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 2 1/2 in. RMP <input type="checkbox"/> PVC 9L Weight 2.58 lbs./ft. Dia. 5 in. to 100 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 3.24		
BROWN Clay	3	12	10. Screen: Manufacturer's name Pumpco Type PVC Dia. 5 <input checked="" type="checkbox"/> Slow gauze .020 Length 30 Set between 20 ft. and 40 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of materials 0.30 X 0.60		
yellow shale	12	21	11. Static water level: 10 ft. below land surface Date 9-17-76		
yellow Lime	21	23	12. Pumping level below land surfaces: ft. after _____ hrs. pumping _____ g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 5 g.p.m.		
shale, grey, Red	23	50	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Limestone, Flinty	50	59	14. Well head completion: CAP Pitless adapter 24 inches above grade		
shale, Red, grey, Bk.	59	100	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.		
			16. Nearest source of possible contamination: ft. 500 Direction E Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	19. Remarks: OWNER WILL INSTALL SLAB		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader DRLg Co Inc LPz License No. _____ Business name _____ Address RT 1 Holton, KS Signed Dale Ashen Date 9-24-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-3

T
 R
 W
 Sec
 1/4
 1/4
 1/4
 NESWNE