

69

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Dec

owner of Well
Hafenstein Const. Co.
Alma Kansas 66401

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66606

1. Location of well:		County Wabaunsee	Fraction SW 1/4 SE 1/4	Section number 10	Township number T 12 S	Range number R 10 E
2. Distance and direction from nearest town or city: in Alma				3. Owner of well: Hafenstein		
Street address of well location if in city: 602 Ohio St.				City, state, zip code: Alma Kans		
4. Locate with "X" in section below: Sketch map: N W E S 1 Mile				6. Bore hole dia. 12 in. Completion date Well depth 86 ft. 12-12-78		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 9.67 lbs./ft. Dia. 5 in. to 86 ft. depth Wall Thickness: inches Dia. 5 in. to 86 ft. depth gage No.		
5. Type and color of material				From	To	10. Screen: Manufacturer's name M.P.I.
old drilled well was				66ft		Type P.V.C. Dia. 5
drilled to 86 ft						Slot 5/16 Length 40
Blue shale				66	86	Set between 40 ft. and 80 ft. ft. and ft.
						Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4" X 1/2"
						11. Static water level: 40 ft. below land surface Date 12-12-78
						12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 18 g.p.m.
						13. Water sample submitted: NA mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
						14. Well head completion: NA <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> 1-2 With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 15 ft. to 5 ft.
						16. Nearest source of possible contamination: Street gutter ft. 50 Direction South type gutter Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. S. Strader Drilling Co 23 Business name Blue Rapids K.S. License No. Address Harold Strader Date 12-13-78 Signed Harold Strader Authorized representative
18. Elevation: 1091' Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland		19. Remarks:				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5