

238

jd

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DAB

1. Location of well:		County Shawnee	Fraction NW NE SE 1/4 SE 1/4 SE 1/4	Section number 28	Township number T 12 S R 14 E E/W	Range number
2. Distance and direction from nearest town or city: 4 N 2 W 1/2 N of Auburn.			3. Owner of well: Ralph Boyle R.R. or street: Box 19208 City, state, zip code: Topeka, KS 66619			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6 1/4 in. Completion date 11-19-78 Well depth 100 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top Soil Sandy clay yellow Sandy clay dk yellow. Lime Shale Very sandy Shale & Sandstone layers Shale sticky Lime Shale sticky Lime		 0 2 19 24 26 42 63 80 83 92 92	 2 14 24 36 42 63 80 83 92 100	9. Casing: Material RMP Height: above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 102 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200		
				10. Screen: Manufacturer's name Sunflower Type RMP Dia. 5 1/2 Slot/gauge 3/16 Length 88' Set between 14 ft. and 102 ft. ft. and _____ ft. Cave pack? no Size range of material _____		
				11. Static water level: _____ mo./day/yr. 27 ft. below land surface Date 11-19-78		
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 80 gal/day		
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 12 ft.		
				16. Nearest source of possible contamination: ft. 100+ Direction East Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 1190 Topography: h <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: owner to install cement slab.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Robison Drilling 316 Business name _____ License No. _____ Address Perry KS. Signed Jack Robison Date 11-19-78 Authorized representative		

12 14 28
Sec 1/4 1/4 NE SE