


1 LOCATION OF WATER WELL: Fraction SW 1/4 SW 1/4 SW 1/4 Section Number 10 Township Number T 12 S Range Number R 15 EW  
 County: SHAWNEE

Distance and direction from nearest town or city street address of well if located within city?  
NE COR. OF 29TH ST AND FAIRLAWN - TOPEKA.

2 WATER WELL OWNER: THOMAS BINKLEY Board of Agriculture, Division of Water Resources  
 RR#, St. Address, Box #: 2219 SW TERRACE #24 Application Number:  
 City, State, ZIP Code: TOPEKA KS. 66611

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:  4 DEPTH OF COMPLETED WELL: 21.7 ft. ELEVATION: 944.26  
 Depth(s) Groundwater Encountered 1. 14.7 ft. 2. - ft. 3. - ft.  
 WELL'S STATIC WATER LEVEL 11.3 ft. below land surface measured on mo/day/yr 07-06-92  
 Pump test data: Well water was - ft. after - hours pumping - gpm  
 Est. Yield 30 gpm: Well water was - ft. after - hours pumping - gpm  
 Bore Hole Diameter - in. to - ft., and - in. to - ft.  
 WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well  
 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)  
 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well  
 Was a chemical/bacteriological sample submitted to Department? Yes - No X; If yes, mo/day/yr sample was submitted -  
 Water Well Disinfected? Yes - No X

5 TYPE OF BLANK CASING USED: 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued - Clamped -  
 1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded -  
2 PVC 4 ABS 7 Fiberglass Threaded X  
 Blank casing diameter 2 in. to 21.7 ft., Dia - in. to - ft., Dia - in. to - ft.  
 Casing height above land surface 20.4 in., weight 54.40 lbs./ft. Wall thickness or gauge No. -  
 TYPE OF SCREEN OR PERFORATION MATERIAL: 7 PVC 10 Asbestos-cement  
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify) -  
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)  
 SCREEN OR PERFORATION OPENINGS ARE: 5 Gauzed wrapped 8 Saw cut 11 None (open hole)  
 1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes  
 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify) -  
 SCREEN-PERFORATED INTERVALS: From 11.7 ft. to 21.7 ft., From - ft. to - ft.  
 From - ft. to - ft., From - ft. to - ft.  
 GRAVEL PACK INTERVALS: From 11 ft. to 21.7 ft., From - ft. to - ft.  
 From - ft. to - ft., From - ft. to - ft.

6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other -  
 Grout Intervals: From 6.2 ft. to 11 ft., From - ft. to - ft., From - ft. to - ft.  
 What is the nearest source of possible contamination: 10 Livestock pens 14 Abandoned water well  
 1 Septic tank 4 Lateral lines 7 Pit privy 11 Fuel storage 15 Oil well/Gas well  
 2 Sewer lines 5 Cess pool 8 Sewage lagoon 12 Fertilizer storage 16 Other (specify below)  
 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 13 Insecticide storage CONTAMINATED  
 Direction from well? - How many feet? -

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
<u>0</u>	<u>1.2</u>	<u>FILL MATERIAL</u>			
<u>1.2</u>	<u>4.8</u>	<u>CLAY-SILTY DK GRV</u>			
<u>4.8</u>	<u>10.2</u>	<u>SILTY CLAY TAN GRV - IRON INCL</u>			
		<u>G.D - GAS D.DEN</u>			
<u>10.2</u>	<u>14.7</u>	<u>SILTY CLAY - TAN - GRV.</u>			
<u>14.7</u>	<u>15.0</u>	<u>CLAY - SANDY - FINE - TAN GRV.</u>			
<u>15.0</u>	<u>16.0</u>	<u>CLAY - SILTY</u>			
<u>16.0</u>	<u>16.2</u>	<u>SILTY CLAY - FINE SAND -</u>			
<u>16.2</u>	<u>20.0</u>	<u>CLAY SILTY TAN GRV - FIRM</u>			
		<u>SCAT. SD. GRAINS.</u>			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 07-02-92 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 479 This Water Well Record was completed on (mo/day/yr) 07-26-92 under the business name of EBBERTS DRILUNG by (signature) [Signature]

OFFICE USE ONLY

T

R

EW

SEC.

1/4

1/4

1/4