

260 WAH

chey loc jd

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

NW ABP

1. Location of well:	County Shawnee	Fraction NW NE 1/4 SE 1/4 NE 1/4	Section number 23	Township number T 12 S 15	Range number R 15E S 12 EW
2. Distance and direction from nearest town or city: FN TOPEKA			3. Owner of well: WOOD VALLEY RACQUET CLUB		
Street address of well location if in city: →			R.R. or street: 2909 W 37th		
4. Locate with "X" in section below:			Sketch map:		
5. Type and color of material			From	To	
BROWN CLAY			0	26	
MOLD'D GRAVEL - loose lime			26	27	
Grey shale			27	50	
Grey Lime			50	53	
Grey shale			53	60	
6. Bore hole dia. 8 in. Completion date 5-18-76			Well depth 60 ft.		
7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug			<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry			<input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock		
<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			9. Casing: Material PVC Height: Above or below		
Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in.			RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.58 lbs./ft.		
Dia. 5 in. to 60 ft. depth			Wall Thickness: inches or		
Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth			gauge No. 258		
10. Screen: Manufacturer's name PUMPCO			Type PVC Dia. 5		
Slot/gauze .020 Length 15			Set between 17 ft. and 32 ft.		
<input checked="" type="checkbox"/> Gravel pack? Size range of material: 20x40			11. Static water level: 15 ft. below land surface		
Date 5-18-76			mo./day/yr.		
12. Pumping level below land surfaces:			ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m.		
ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m.			Estimated maximum yield 8 g.p.m.		
13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Date		
14. Well head completion: CAPPED			Pitless adapter 24 inches above grade		
15. Well grouted? <input checked="" type="checkbox"/>			With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete		
Depth: From 0 ft. to 10 ft.			16. Nearest source of possible contamination: ft. 300 Direction E Type DRAINAGE		
Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			17. Pump: <input type="checkbox"/> Not installed		
Manufacturer's name JACUZZI			Model number 554B HP 1/2 Volt 230		
Length of drop pipe 55 ft. capacity 10 g.p.m.			Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating			<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 924 ft. m			19. Remarks: owner will install slab		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
			Business name Stadler Dalg Co Inc License No. 182		
			Address RT1 Holton, KS		
			Signed Dale Peterson Date 5-20-76		
			Authorized representative		

12 15 23 1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5