USE TYPEWRITER OR BALL
POINT PEN–PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Douglas	Fraction NW NW 1/4 NE 1/4 NW 1/4	Section number 10	Township number T 12 S	Range number R 21E E/W

2. Distance and direction from nearest town or city: W 2 N 1/2 W of Linwood.
Street address of well location if in city:

3. Owner of well: Leonard Burnett
R.R. or street: R 1 Box 17B
City, state, zip code: Linwood Ks 66052

4. Locate with "X" in section below: Sketch map:

```
         N
    |  X  |
  - NW - -|- - NE -
W    |    |         E
  - SW - -|- - SE -
    |    |
         S
  |—— 1 Mile ——|
```

☐ Home
← Q well

6. Bore hole dia. 6 1/4 in. Completion date 2/19/78
Well depth 83 ft.

7. X Cable tool ___ Rotary ___ Driven ___ Dug
___ Hollow rod ___ Jetted ___ Bored ___ Reverse rotary

8. Use: X Domestic ___ Public supply ___ Industry
___ Irrigation ___ Air conditioning ___ Stock
___ Lawn ___ Oil field water ___ Other

9. Casing: Material PTS Height Above or below
Threaded ___ Welded ___ Surface 24 in.
RMP X PVC ___ Weight ___ lbs./ft.
Dia 5 in. to 53 ft. depth Wall Thickness: inches or
Dia ___ in. to ___ ft. depth gage No. 200

10. Screen: Manufacturer's name Sunflower
Type RMP Dia. 5"
Slot/gauze 3/16 Length 73'
Set between 10 ft. and 53 ft.
___ ft. and ___ ft.
Gravel pack? YES Size range of material 1/4-1/2

5. Type and color of material	From	To
Top Soil	0	1
Clay yellow	1	8
Sandstone yellow	8	10
Clay	10	21
Sandy Shale	21	55
Lime	55	57
Sandy Shale	57	83

11. Static water level: mo./day/yr.
9 ft. below land surface Date 2/19/78

12. Pumping level below land surfaces:
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield 15 g.p.m.

13. Water sample submitted: mo./day/yr.
___ Yes X No Date ___

14. Well head completion:
___ Pitless adapter 24 Inches above grade

15. Well grouted? yes
With: X Neat cement ___ Bentonite ___ Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:
ft. 100+ Direction West Type Septic
Well disinfected upon completion? X Yes ___ No

17. Pump: X Not installed
Manufacturer's name ___
Model number ___ HP ___ Volts ___
Length of drop pipe ___ ft. capacity ___ g.p.m.
Type:
___ Submersible ___ Turbine
___ Jet ___ Reciprocating
___ Centrifugal ___ Other

(Use a second sheet if needed)

18. Elevation: ◯ 890
Topography:
X Hill
X Slope
___ Upland
___ Valley

19. Remarks: Owner to install slab.

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report
is true to the best of my knowledge and belief.
Business name Robison Drilling 316 License No.
Address Perry Ks.
Signed Jack Stehn Date 2/19/78
Authorized representative