

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment
Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Johnson		Fraction SE NE SE SW 1/4 SW 1/4 NE 1/4		Section number 19	Township number T 12 S R	Range number 22E E/W
2. Distance and direction from nearest town or city: 4 mi. W. De Soto				3. Owner of well: Riverview Farms		
Street address of well location if in city:				R.R. or street:		
				City, state, zip code: De Soto, Kansas 66018		
4. Locote with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 7/77		
				Well depth 52 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12" in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia 12 in. to 30 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. _____		
5. Type and color of material		Well #1		10. Screen: Manufacturer's name _____		
		From	To	Type Irrigator Dia. 12"		
Drift		0	2	Slot/gauze 100 Length 20'		
Fine Sand		2	15	Set between 32 ft. and 52 ft.		
Coarse Sand		15	25	_____ ft. and _____ ft.		
Sand, Mixed With Clay		25	32	Gravel pack? yes Size range of material 1/8"		
Sand & Gravel		32	52	11. Static water level: _____ mo./day/yr. 8 ft. below land surface Date 7/77		
Limestone		52		12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 850 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes bxxx No _____ Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 20 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 1200 Direction N Type river Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name Worthington Model number 12M75 HP 60 Volts _____ Length of drop pipe 40 ft. capacity 750 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Cullum & Brown, Inc 121 Business name _____ License No. _____ Address No. Kansas City, MO Signed Howard L. L. Date 8/23/77 Authorized representative		
18. Elevation: 788 ft.	19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 12 S R 22E
 Sec 19 SW SW NE