

53

To B.W.S.
6-29-79

CF
VR

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Johnson	Fraction NE 1/4 SW 1/4 SW 1/4	Section number 24	Township number T 12 S	Range number R 22	(B)W
2. Distance and direction from nearest town or city: Street address of well location if in city:		2 1/2 Miles East of Desoto, Kansas		3. Owner of well: City of Olathe R.R. or street: City, state, zip code:			
4. Locate with "X" in section below: N W E S 1 Mile				Sketch map: 			
5. Type and color of material				From	To	6. Bore hole dia. 60 in. Completion date 10-30-78 Well depth 684 ft. 53' 1"	
Topsoil				0' 0"	10"	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Sandy Silt				1' 0"	16' 0"	8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Brown Fine Sand				16' 0"	27' 0"	9. Casing: Material Sta. Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 15' in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 157.5 lbs./ft. Dia. 30 in. to 30 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 0.500	
Brown Coarse To Medium Sand				27' 0"	37' 0"	10. Screen: Manufacturer's name Johnson Cook Type Wire Wound Dia. 30" Slot/gauze 100 Length 23' Set between 30 ft. and 33 ft. Gravel pack? yes Size range of material 1/25"	
Gray Coarse To Medium Sand				37' 0"	45' 0"	11. Static water level: 27.9 ft. below land surface Date 10-31-78 mo./day/yr. 10-31-78	
Gray Coarse To Medium Sand Some Gravel				45' 0"	54' 0"	12. Pumping level below land surfaces: 35.25 ft. after 6 hrs. pumping 692 g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 700 g.p.m.	
						13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 11-13-78	
						14. Well head completion: <input type="checkbox"/> Pitless adapter 15' Inches above grade	
						15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 08 ft. to 22 ft.	
						16. Nearest source of possible contamination: ft. 200 Direction East Type Kaw River Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co. Inc. 149 Business name _____ License No. _____ Address 1010 W 39th K.C. Mo Signed Paul S. Hill Date 12-20 Authorized representative	
18. Elevation: 172 ft. Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: Well # 7					

T 12 S 22 R 24 NE SW SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5