


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Johnson	Fraction SW NW SE NE 1/4	Section number 28	Township number T 12	Range number S R 22 E E/W
2. Distance and direction from nearest town or city: De Soto Kansas Street address of well location if in city:				3. Owner of well: City of De Soto, Kansas R.R. or street: City Hall City, state, zip code: De Soto, Kansas		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 18 in. Completion date 2/75 Well depth 43 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Fill & Overburden		0	6	9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 12 in. to 34 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .375		
Silty, Sandy C lay		6	26	10. Screen: Manufacturer's name Johnson Type 304 S. Dia. 10" Slot/gauze 80 Length 10' Set between 31 ft. and 41 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8		
Fine Sand W/ Clay lenses		26	30	11. Static water level: 2/75 mo./day/yr. 19.9 ft. below land surface Date		
Sand Medium to Coarse		30	36	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 450 g.p.m.		
Sand Medium		36	41	13. Water sample submitted: ____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date unknown		
Limestone		41		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter ____ inches above grade		
				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 15 ft. to 5 ft.		
				16. Nearest source of possible contamination: ft. 1000 Direction N Type river Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: Not installed Manufacturer's name Jacuzzi Model number 75s6h HP 1/2 Yield 230 Length of drop pipe 30 ft. capacity ____ g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 784 pm Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: contours aren't clear		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Cullum & Brown, Inc 121 Business name N. K. G. Co. 64116 License No. Address De Soto, Mo. 64116 Signed James R. L. Date 2/27/75 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5