	County	Fraction NE NY SE		Section	number	Township number Range number
1. Location of well:	Leavenworth	SE 1/4 SE 1/4 N	E 1/4	1 6		T 12 South S R 22 East E/W
2. Distance and dire	ction from nearest town or city: 2 1	<u> </u>	-	ner of wel		Mr. Larry Wolf
·				street:		323 Cornell
City,				City, state, zip code:		Bonner Springs, Ks. 66912
4. Locate with "X" in section below: N						6. Bore hole dia. 81 in. Completion date 8/2/7 Well depth 120 ft.
	1	•				7Cable tool X Rotary Driven Dug
NW	NE					Hollow rod Jetted Bored Reverse rotary
<u>•</u>						8. Use: X Domestic Public supply Industry
<u>≅</u> W	1 6					Irrigation Air conditioning Stock Lawn Oil field water Other
sw	SE					9. Casing: Material PL Height: Above or KN
	1					Threaded Welded X Surface 18 in
S 1 → −−− 1 M						RMPPVC_XWeightlbs./ft. Dia. 5 in. to 120 ft. depth Wall Thickness: inches or
5. Type and color of material				From	То	Dia in. to ft. depth gage No•265
Top Soil				0	1	10. Screen: Manufacturer's name
Clay		" ' 		1	5	Type Slotted Pipe Dig. 5
Lime Lage				5	9	Slot/gauze 06 1/16 Length 20Ft Set between 50 ft. and 70 ft.
						ft, andft.
Clay				9	19	Gravel pack? X Size range of material 1/8 to
Shale				19	48	11. Static water level: mo./day/yr32 ft. below land surface Date 8/2/77
Sandy Shale	9			48	54	12. Pumping level below land surfaces:
Sandstone	(Gray)			54	66	ft. after hrs. pumping g.p.m ft. after hrs. pumping g.p.m.
Sandstone	(Orange)			66	72	Estimated maximum yield 20 Gal g.p.m. 13. Water sample submitted: No mo./day/yr.
				†		Yes No Date
Sandstone (Gray)				72	118	14. Well head completion:
Line				118	120	X Pitless adapter 18 Inches above grade 15. Well grouted? Yes
						With: X Neat cement Bentonite Concrete
						Depth; From 3 ft. to 15 ft.
	•			-		16. Negrest source of possible contamination: ft. 200 Direction E Type Septic
						Well disinfected upon completion? X Yes No
						17. Pump: X Not installed Manufacturer's name
				1		Model number HP Volts
				-		Length of drop pipe ft. capacityg.p.m. Type:
						Submersible Turbine
	// lea = =================================	heat if mondad)				Jet Reciprocating
18. Elevation:	(Use a second s	neer it needed)		.L	I	Centrifugal Other 20. Water well contractor's certification:
alkl						This well was drilled under my jurisdiction and this report
Topography:						is true to the best of my knowledge and belief. Breuer, Inc. 174
Hill						Business name License No.
Slope						Address Box 117, Basehor, Ks.
Upland Valley						Signed Authorized representative Date