

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

Bonner Springs

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wyandotte	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 6	Township number T 12 S	Range number R 23 E/W
2. Distance and direction from nearest town or city: 2 miles south of Bonner Springs				3. Owner of well: Mr. Tom Gray R.R. or street: Route 2 City, state, zip code: Bonner Springs, Kansas		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 11-17-77 Well depth 43 ft.		
		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PI Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 144 lbs./ft. Dia. 5 in. to 4 1/4 ft. depth Wall Thickness: inches or Dia. 5 in. to 4 1/4 ft. depth gage No. 265		
5. Type and color of material				From	To	10. Screen: Manufacturer's name (Slotted Pipe) Vinylplex, Inc.
Top Soil				0	5	Type PVC Dia. 5"
Clay				5	15	Slot/gauze .06 1/16 Length 8'
Sandy Clay				15	25	Set between 35 ft. and 43 ft.
Sandy Slate				25	35	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 - 1/8
Sand & Gravel				35	43	11. Static water level: 26 ft. below land surface Date 11-18-77
Lime				43		12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 15 g.p.m.
						13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
						14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade
						15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 15 ft.
						16. Nearest source of possible contamination: ft. 200 Direction south type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BREUER, INC. 174 Business name _____ License No. _____ Address Box 1472, Basenor, Ks. 66607 Signed <i>[Signature]</i> Date 11/18/77 Authorized representative
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5