

WATER WELL RECORD

Form WWC-5


Division of Water Resources; App. No.

1 LOCATION OF WATER WELL: County: Dickinson Fraction: NE 1/4 NE 1/4 NW 1/4 Section Number: 34 Township Number: T 12 S Range Number: R 30 W

Distance and direction from nearest town or city street address of well if located within city? From Abilene 60 9 miles East on I 70 to 43 Hwy 60 2 mile North East

2 WATER WELL OWNER: RR#, St. Address, Box # 2628 Nail Rd City, State, ZIP Code Abilene, KS 67410

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: N S W E



4 DEPTH OF COMPLETED WELL: 140 ft. Depth(s) Groundwater Encountered (1) 90 ft. (2) ft. (3) ft. WELL'S STATIC WATER LEVEL 80 ft. below land surface measured on mo/day/yr. Pump test data: Well water was ft. after hours pumping gpm Est. Yield 30 gpm: Well water was ft. after hours pumping gpm

5 TYPE OF CASING USED: 1 Steel 3 RMP (SR) 5 Wrought Iron 8 Concrete tile CASING JOINTS: 7 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) 7 Fiberglass

Blank casing diameter 5 in. to 120 ft. Diameter. Casing height above land surface 5 in., Weight 509.40 lbs./ft. Wall thickness or gauge No.

TYPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel 3 Stainless Steel 5 Fiberglass 7 PVC 9 ABS 11 Other (Specify) 2 Brass 4 Galvanized Steel 6 Concrete tile 8 RM (SR) 10 Asbestos-Cement 12 None used (open hole)

SCREEN OR PERFORATION OPENINGS ARE: 1 Continuous slot Mill slot 5 Guazed wrapped 7 Torch cut 9 Drilled holes 11 None (open hole) 2 Louvered shutter 4 Key punched 6 Wire wrapped 8 Saw Cut 10 Other (specify)

SCREEN-PERFORATED INTERVALS: From 120 ft. to 140 ft. GRAVEL PACK INTERVALS: From 25 ft. to 140 ft.

6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other Grout Intervals: From 5 ft. to 25 ft.

What is the nearest source of possible contamination: None Close

Direction from well? How many feet?

Table with columns: FROM, TO, LITHOLOGIC LOG, FROM, TO, PLUGGING INTERVALS. Rows include: 0-1 Top Soil, 1-9 Brown Clay, 9-12 Limestone, 12-50 Tan Shale, 50-58 Limestone, 58-64 Gray, 64-66 Limestone, 66-90 Brown Shale, 90-110 Limestone.

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was constructed, reconstructed, or plugged under my jurisdiction and was completed on (mo/day/year) 8/23/2006 and this record is true to the best of my knowledge and belief.

INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send three copies to Kansas Department of Health and Environment, Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka, Kansas 66612-1367.