

sent 3-17-76

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Dickinson</b>	Fraction <b>SW 1/4 NE 1/4 NW 1/4</b>	Section number <b>30</b>	Township number <b>T 12 S R 4</b>	Range number <b>4</b>	<b>(E)W</b>
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:		<b>Calvin Steele</b> <b>Chapman, Kansas 67431</b>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>8</u> in. Completion date <u>10/4/75</u> Well depth <u>125</u> ft.			
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Fine sand		0	7	9. Casing: Material <u>plst</u> Height <u>Above</u> or below Threaded <input type="checkbox"/> Welded <u>gl</u> Surface <u>18</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>        </u> lbs./ft. Dia. <u>5</u> in. to <u>125</u> ft. depth; Wall Thickness: inches or Dia. <u>        </u> in. to <u>        </u> ft. depth; gage No. <u>0.214</u>			
Limestone and little flint		7	20	10. Screen: Manufacturer's name <u>Western Plastics</u> Type <u>PVC</u> Dia. <u>5"</u> <u>Slot/gauze 3/32</u> Length <u>49'</u> Set between <u>76</u> ft. and <u>125</u> ft. <u>        </u> ft. and <u>        </u> ft.			
Yellow clay		20	27	Gravel pack? <u>Yes</u> Size range of material <u>1/16 to 3/8</u>			
Limestone and black flint		27	33	11. Static water level: <u>80</u> ft. below land surface Date <u>10/4/75</u> mo./day/yr.			
Clay		33	36	12. Pumping level below land surfaces: <u>        </u> ft. after <u>        </u> hrs. pumping <u>        </u> g.p.m. <u>        </u> ft. after <u>        </u> hrs. pumping <u>        </u> g.p.m. Estimated maximum yield <u>15</u> g.p.m.			
Rock		36	41	13. Water sample submitted: <u>        </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u>        </u>			
Clay		41	43	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>18</u> Inches above grade			
Red shale		43	46	15. Well grouted? <u>Yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
Gray shale		46	68	16. Nearest source of possible contamination: fr. <u>        </u> Direction <u>        </u> Type <u>        </u> Well disinfected upon completion? <u>Yes</u> Yes <input type="checkbox"/> No			
Red shale		68	70	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>        </u> Model number <u>        </u> HP <u>        </u> Volts <u>        </u> Length of drop pipe <u>        </u> ft. capacity <u>        </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
Rock and flint		70	86	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rader Drilling Co.</u> 194 Business name License No. Address <u>Carlton, Kans. 67429</u> Signed <u>Bruce E. Rader</u> Date <u>11-17</u> Authorized representative			
Clay and shale		86	89				
Rock		89	93				
Shale and clay		93	100				
Rock		100	125				
(Use a second sheet if needed)							
18. Elevation:		19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Customer probably won't build a house for about 1 year.					

12 - 40 30 SW NE NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5