

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Greary CO	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 1	Township number T 12 S R 4 E/W	Range number 4
2. Distance and direction from nearest town or city: 7 W OF JUNCTION CITY			3. Owner of well: RICHARD ROTHFUS - TRACT F R.R. or street: 1012 HIGHLAND City, state, zip code: JUNCTION CITY, KS			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date _____ Well depth 140 ft. 5-13-77		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 29 in. RMP <input type="checkbox"/> PVC 94 Weight 2.58 lbs./ft. Dia. 5 in. to 140 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 258		
				10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5 18 gauze .060 Length 15 Set between 97 ft. and 112 ft. ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 1/8		
				11. Static water level: _____ mo./day/yr. 60 ft. below land surface Date 5-13-77		
				12. Pumping level below land surfaces: AIR TEST _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 29 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 150 Direction S Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		OWNER TO INSTAL SLAB		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRADER Dalg Co Inc 182 Business name License No. _____ Address RT 1 HOLTAN, KS Signed Dale Fisher Date 5-13-77 Authorized representative		

T
R
W
Sec
1/4
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5