

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>GEARY</u>	Township name <u>JEFFERSON SW 1/4 SW 1/4 NW 1/4</u>	Fraction	Section number <u>4</u>	Town number <u>12 HS</u>	Range number <u>5E</u>
Distance and direction from nearest town or city: <u>940 GRANT JUNCTION CITY</u>				3 Owner of well: <u>FASHION MASTER CLEANERS</u>		
Street address of well location if in city:				Address: <u>940 GRANT JCT. CITY, KS.</u>		
Locate with "X" in section below:		Sketch map:		4 Well depth: <u>50</u> ft. Date of completion <u>10-7-75</u> Well diameter <u>10</u> in.		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
2 Type and color of material				From	To	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>
<u>Top Soil</u>				<u>0</u>	<u>5</u>	7 Casing: Material <u>PVC</u> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in. Diam. <u>5</u> in. to <u>50</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>5</u> in. to <u>50</u> ft. depth
<u>Brown Clay</u>				<u>5</u>	<u>30</u>	8 Screen: Manufacturer <u>Pump Co</u> Type <u>PVC</u> Dia. <u>5"</u> Slot/gauze <u>.080</u> Length <u>5'</u> Set between <u>45</u> ft. and <u>50</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/4"</u>
<u>Coarse Sand</u>				<u>30</u>	<u>40</u>	9 Static water level: <u>NOT MEASURED</u> <u>28</u> ft. below land surface Date <u>10-7-75</u> <u>WNC</u>
<u>Coarse sand & GRAVEL</u>				<u>40</u>	<u>50</u>	10 Pumping level below land surfaces: <u>AIR TEST</u> ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>100</u> g.p.m.
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____
						12 Well head completion: <u>CAPPED</u> <input type="checkbox"/> Pitless adapter <u>24</u> <input checked="" type="checkbox"/> Inches above grade
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>0</u> ft. to <u>10</u> ft.
						14 Nearest source of possible contamination: ft. <u>80</u> Direction <u>SE</u> Type <u>S-T</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation <u>owner will install slab</u>				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Strader Dalg Co Inc 182</u> Business name _____ License No. _____ Address <u>671 Walton, KS.</u> Signed <u>Dale Ashburn</u> Date <u>10-13-75</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						