

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: County Geary Fraction SW 1/4 SW 1/4 SW 1/4 Section number 9 Township number T 12 S R 5 EA

2. Distance and direction from nearest town or city: 2 W . 5 S **3. Owner of well:** Richard Rothfus
Street address of well location if in city: OF JUNCTION R.R. or street: RR 3
City, state, zip code: JUNCTION CITY, KS 66441

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. 8 in. **Completion date** 7-5-78
Well depth 160 ft.

7. Cable tool **Rotary** **Driven** **Dug**
 Hollow rod **Jetted** **Bored** **Reverse rotary**

8. Use: **Domestic** **Public supply** **Industry**
 Irrigation **Air conditioning** **Stock**
 Lawn **Oil field water** **Other**

9. Casing: Material PVC Height: Above or below
Threaded Welded Surface 24 in.
RMP PVC 9/2 Weight 2.50 lbs./ft.
Dia. 5 in. to 160 ft. depth Wall Thickness: inches or
Dia. 5 in. to 160 ft. depth gage No. 1274

5. Type and color of material	From	To
<u>TOP SOIL</u>	<u>0</u>	<u>4</u>
<u>Clay, yellow</u>	<u>4</u>	<u>39</u>
<u>Shale, yellow, grey, soft</u>	<u>39</u>	<u>68</u>
<u>Limestone, brown</u>	<u>68</u>	<u>75</u>
<u>Shale, grey, yellow, red</u>	<u>75</u>	<u>112</u>
<u>Limestone, yellow, loose</u>	<u>112</u>	<u>130</u>
<u>shaley limestone, grey,</u>	<u>130</u>	<u>160</u>

10. Screen: Manufacturer's name PUMPER M.P.I.
Type PVC Dia. 5
Slot/gauze 1/20 Length 90
Set between 100 ft. and 140 ft.
ft. and _____ ft.
Gravel pack? Size range of material 10/20, 16/20

11. Static water level: _____ mo./day/yr.
65 ft. below land surface Date 7-5-78

12. Pumping level below land surfaces:
_____ ft. after _____ hrs. pumping _____ g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield 15 g.p.m.

13. Water sample submitted: _____ mo./day/yr.
 Yes No Date _____

14. Well head completion: CAP
 Pitless adapter 24 Inches above grade

15. Well grouted?
With: Neat cement Bentonite Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:
ft. 300 Direction W Type SEPTIC
Well disinfected upon completion? Yes No

17. Pump: **Not installed**
Manufacturer's name _____ HP _____ Volts _____
Length of drop pipe _____ ft. capacity _____ g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other _____

(Use a second sheet if needed)

18. Elevation: Topography: Hill Slope Upland Valley

19. Remarks: OWNER TO INSTALL SLAB

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
STRADER DRIG CO 182
Business name License No.
Address RT 1 HOLTEN, KS
Signed Dale Ashman Date 7-6-78
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5