


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Geary	Township name Lyons	Fraction Center of NE 40 of SW 1/4	Section number 36	Town number 12	Range number 5
Distance and direction from nearest town or city: 4 miles South Junction City, Ks			3 Owner of well: Lutheran Church in America Central States Synod Address: 3527 Broadway Kansas City, Mo 64111			
Locate with "X" in section below:		Sketch map:				
N 		CA				
2		Type and color of material		From	To	4 Well depth: 80 ft. Date of completion MAY 12 Well diameter 8 1/2 in. 10" 5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> _____ 7 Casing: Material Plastic Height: above/below _____ Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP Diam. 7" O.D. Weight 5 lbs./ft. 7 1/2 in. to 40 ft. depth Drive shoe? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No 7 1/2 in. to 45 ft. depth at lower end
		Top Soil		0	3	8 Screen: Manufacturer Hess or Lowell Type RMP Dia. 5" Slot/gauze 10SD Length 20 Set between 60 ft. and 30 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4 x 1/8
		RED CLAY		4	20	9 Static water level: 41 ft. below land surface Date 92 MAY 12
		YELLOW CLAY		21	30	10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping _____ g.p.m. ____ ft. after ____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 g.p.m. at 40'
		GRAVEL		31	40	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
		YELLOW LIMESTONE		41	46	12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade N/A
		BLUE SHALE		47	80	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 15 ft. to 5 ft.
						14 Nearest source of possible contamination: N/A 41 ft. Field Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation						17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Drilling Co Business name Blue Rapids License No. 237 Address Harriet Strader Date May 14 Signed _____ Authorized representative