

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Geary	Fraction NE 1/4 SE 1/4 NE 1/4	Section number 18	Township number T 12 S R 6	Range number 6
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. <u>8</u> in. Completion date _____ Well depth <u>115</u> ft. <u>10/15/76</u>		
			7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material <u>PIST</u> Height: Above or below _____ Threaded _____ Welded <u>gl</u> Surface <u>18</u> in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. <u>5</u> in. to <u>115</u> ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. <u>0.258</u>		
			10. Screen: Manufacturer's name _____ <u>Western Plastics</u> Type <u>RMP</u> Dia. <u>5"</u> Slot/gauze <u>3/32</u> Length <u>40</u> Set between <u>75</u> ft. and <u>115</u> ft. _____ ft. and _____ ft. Gravel pack? <u>Yes</u> Size range of material <u>1/16 to 3/8</u>		
Clay			From	To	11. Static water level: _____ mo./day/yr. <u>80</u> ft. below land surface Date <u>10/15/76</u>
Red and gray shale			0	21	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>6</u> g.p.m.
Limestone and flint			21	47	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Gray shale			47	55	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>18</u> Inches above grade
Limestone & flint			55	74	15. Well grouted? <u>Yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
Gray shale			74	85	16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <u>Yes</u> Yes _____ No
Flint Flint			85	86	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Red shale			86	87	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rader Drilling Co.</u> <u>194</u> Business name License No. Address <u>Carlton, Kans.</u> <u>67429</u> Signed <u>Brant E. Rader</u> Date <u>11-30</u> Authorized representative
Hollow limestone			87	101	
Blue, hard clay			101	106	(Use a second sheet if needed)
Blue and gray hard shale			106	108	
Blue and gray hard shale			108	115	18. Elevation:
19. Remarks: Customer will construct the concrete slab.			Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		

T
R
E
S
E
C
1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5