

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Dickinson	Fraction NW 1/4 SE 1/4 SW 1/4	Section number 17	Township number T 13 S R 1	Range number 1
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
1 mile east of Solomon			Charles Clemence R.R. # 1 Solomon, Kansas			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>8</u> in. Completion date _____ Well depth <u>46</u> ft. <u>9/15/77</u>	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Hard clay		0	28	9. Casing: Material <u>plst</u> Height: Above ground _____ Threaded _____ Welded <u>gl</u> Surface <u>18</u> in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. <u>5</u> in. to <u>46</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>0.258</u>		
Hollow rock		28	35	10. Screen: Manufacturer's name _____ <u>Western Plastics</u> Type <u>RMP</u> Dia. <u>5"</u> Slot/gouze <u>3/32</u> Length <u>20'</u> Set between <u>26</u> ft. and <u>46</u> ft. _____ ft. and _____ ft.		
Blue		35	46	Gravel pack? <u>yes</u> Size range of material; <u>1/16 to 3/8</u>		
				11. Static water level: _____ mo./day/yr. <u>27</u> ft. below land surface Date <u>9/15/77</u>		
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>304</u> g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>18</u> inches above grade		
				15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				<input checked="" type="checkbox"/> Nearest source of possible contamination: ft. <u>14m</u> Direction <u>SW</u> Type <u>septic</u> Well disinfected upon completion? _____ Yes _____ No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rader Drilling Co.</u> <u>194</u> Business name License No. Address <u>Carlton, Kansas</u> Signed <u>Bruce E. Rader</u> Date <u>10-26-77</u> Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			<div style="float: right; text-align: right; font-size: 2em; font-weight: bold;"> T 13 S R 1 Sec 17 NW 1/4 SE 1/4 SW 1/4 </div>			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5