



USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County: Shawnee	*Fraction: NW 1/4 SW 1/4 NW 1/4	Section number: 20	Township number: T 13 S	Range number: R 14 E
2. Distance and direction from nearest town or city: 4W 1/4 n of Auburn			3. Owner of well: Louis Atwood		
Street address of well location if in city:			R.R. or street: RR #7		
			City, state, zip code: Topeka, Ks. 66604		
<input checked="" type="checkbox"/> Locate with "X" in section below: 		Sketch map: feed lot 		6. Bore hole dia. 6 1/4 in. Completion date 4-23-79 Well depth 82 ft.	
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Top Soil		0	2	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Sandstone yellow		2	14	9. Casing: Material P15 Height Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 82 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 200	
Shale grey		14	41	10. Screen: Manufacturer's name Sunflower Type RMP Dia. 5 1/2 Slot/gauze 0.50 Length 42' Set between 40 ft. and 82' ft. _____ ft. and _____ ft. Gravel pack? no Size range of material _____	
Lime broken		41	45	11. Static water level: _____ mo./day/yr. 32 ft. below land surface Date 4-23-79	
Shale grey		45	82	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10+ g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
				15. Well grouted? yes With: <input checked="" type="checkbox"/> neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 21 ft.	
				16. Nearest source of possible contamination: ft. 100+ Direction North Type Feed lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name Robison Drilling 316 License No. _____ Address Perry Ks Signed Jack Robison Date 4-23-79 Authorized representative	
18. Elevation: 1150 ft. pm	19. Remarks: owner to install cement slab				
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T
R
E
S
E
C
1/4 1/4 NW SW NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5