

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Dickinson	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 4	Township number T 13 S R 2	Range number EW
2. Distance and direction from nearest town or city: Street address of well location if in city: 2 miles north of Abilene			3. Owner of well: Dr. D. C. Chaffee R.R. or street: R.R. # 1 City, state, zip code: Abilene, Kansas 67410		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 3 ACRES WELL 150' SEPTIC TANK FIELD		
5. Type and color of material			From	To	6. Bore hole dia. 8 in. Completion date 5-6-76 Well depth 76 ft.
Yellow clay			0	12	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Rock			12	15	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Gray clay			15	18	9. Casing: Material PLST Height: Above or below 18 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> RMP <input checked="" type="checkbox"/> PVC Weight 18 lbs./ft. Dia. 5 in. to 76 ft. depth Wall thickness: inches or gage No. 0.258
Red			18	31	10. Screen: Manufacturer's name Western Plastics Type RMP Dia. 5" Slot/gauze 3/32 Length 40 Set between 36 ft. and 76 ft. Gravel pack? Yes Size range of material 1/16 to 3/8
Gray			31	36	11. Static water level: 36 ft. below land surface Date 5-6-76 mo./day/yr.
Yellow clay & rock			36	54	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 12+ g.p.m.
Water bearing rock			54	56	13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
Blue clay and shale			56	76	14. Well head completion: <input type="checkbox"/> Pitless adapter 18 Inches above grade
Red clay			76		15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: septic tank ft. 200' Direction south Type tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					(Use a second sheet if needed)
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rader Drilling Co. 194 Business name License No. _____ Address Carlton, Kansas 67429 Signed Bruce P. Rader Date 8-25 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue, and pink copies to the Department of Health and Environment

Form WWC-5