

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

Sent 10/8/75

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Dickinson</b>	Township name <b>Grant</b>	Fraction <b>SE 1/4 NW 1/4 SW 1/4</b>	Section number <b>9</b>	Town number <b>T133</b>	Range number <b>R2E</b>
Distance and direction from nearest town or city: Street address of well location if in city: <b>1702 Beekman Place Abilene, Kansas</b>				3 Owner of well: <b>Wayne Jones</b> Address: <b>1702 Beekman Place Abilene, Kansas 67410</b>		
Locate with "X" in section below:		Sketch map:				
2 Type and color of material				From	To	
Top soil and clay				0	11	
Rock				11	12	
Gray shale				12	20	
Red shale				20	31	
Shale and rock				31	51	
Hard shale				51	53	
Blue				53	60	
(use a second sheet if needed)						
16 Remarks: elevation				17 Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Rader Drilling Co. 194</b> Business name License No. Address <b>Carlton, Kansas 67429</b> Signed <b>Brant E Rader</b> Date <b>7-29-75</b> Authorized representative		

4 Well depth: **60** ft. Date of completion **7/19/75**  
Well diameter **8** in.

5  Cable tool  Rotary  Driven  Dug  
 Hollow rod  Jetted  Bored  Reverse rotary

6 Use:  Domestic  Public supply  Industry  
 Irrigation  Air conditioning  Commercial  
 Test well

7 Casing: Material **RMP** Height: above/below  
Threading  Welded  Surface **18** in.  
Diam. \_\_\_\_\_ Weight \_\_\_\_\_ lbs./ft. \_\_\_\_\_  
**5** in. to **60** ft. depth Drive shoe?  Yes  No  
\_\_\_\_\_ in. to \_\_\_\_\_ ft. depth

8 Screen:  
Manufacturer **Western Plastics**  
Type **RMP** Dia. **5** in.  
Slot/gauze **3/32** in. Length **2 1/2** in.  
Set between **25** ft. and **60** ft.  
Fittings: **1/16 to 3/8**  
Gravel pack  Yes  No Size range of material \_\_\_\_\_

9 Static water level:  
**30** ft. below land surface Date \_\_\_\_\_

10 Pumping level below land surfaces:  
\_\_\_\_\_ ft. after \_\_\_\_\_ hrs. pumping \_\_\_\_\_ g.p.m.  
\_\_\_\_\_ ft. after \_\_\_\_\_ hrs. pumping \_\_\_\_\_ g.p.m.  
Estimated maximum yield **10** g.p.m.

11 Water sample submitted:  
 Yes  No Date \_\_\_\_\_

12 Well head completion: **capped**  
 Pitless adapter  Inches above grade

13 Well grouted?  Yes  No  
 Neat cement  Bentonite  \_\_\_\_\_  
Depth: From **0** ft. to **10** ft.

14 Nearest source of possible contamination: **Sewer none live**  
ft. **50** Direction **W** Type \_\_\_\_\_  
Well disinfected upon completion?  Yes  No

15 Pump:  Not installed  
Manufacturer's name \_\_\_\_\_  
Model number \_\_\_\_\_ HP \_\_\_\_\_ Volts \_\_\_\_\_  
Length of drop pipe \_\_\_\_\_ ft. capacity \_\_\_\_\_ g.m.p.  
Type:  
 Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other