

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Dickinson	Fraction SE 1/4 NE 1/4 NW 1/4	Section number 19	Township number T 13 S R 2	Range number 2	(E)W
2. Distance and direction from nearest town or city: Street address of well location if in city: 107 Westwood Drive Abilene, Kansas 67410				3. Owner of well: Robert Holeman R.R. or street: 107 Westwood Drive City, state, zip code: Abilene, Kansas 67410			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>8</u> in. Completion date <u>3/10/76</u> Well depth <u>80</u> ft.		7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		9. Casing: Material <u>Plst</u> Height: Above or Below Threading: <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u> </u> lbs./ft. Dia. <u>5</u> in. to <u>80</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gauge No. <u>0.258</u>	
5. Type and color of material				From	To	10. Screen: Manufacturer's name <u>Western Plastics</u> Type <u>PVC</u> Dia. <u>5"</u> Slot/gauze <u>3/32</u> Length <u>40</u> Set between <u>40</u> ft. and <u>80</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>1/16 to 3/8</u>	
Sandy clay				0	3	11. Static water level: <u>42</u> ft. below land surface Date <u>3/10/76</u> mo./day/yr.	
Sand				3	9	12. Pumping level below land surfaces: <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>10</u> g.p.m.	
Limestone				9	16	13. Water sample submitted: <u> </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u> </u>	
Gray clay				16	21	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>18</u> inches above grade	
Red clay				21	46	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
Limestone rock				46	57	16. Nearest source of possible contamination: ft. <u>60'</u> Direction <u>S.W.</u> Type <u>Sewer</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Shale				57	68	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Rada</u> Model number <u>9D9P051</u> HP <u>1/2</u> Volts <u>220</u> Length of drop pipe <u>70</u> ft. capacity <u> </u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rader Drilling Co.</u> <u>194</u> Business name License No. <u> </u> Address <u>Carlton, Kansas 67429</u> Signed <u>Brad E Rader</u> Date <u>5-11-76</u> Authorized representative	
18. Elevation:		19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley							

13
 2
 19
 SE
 NW
 1/4
 1/4
 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5