

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Dickinson	Fraction SW 1/4 NE 1/4 NE/4	Section number 21	Township number T 13 S R 2 E	Range number 2
2. Distance and direction from nearest town or city: 509 SE 4th Street, Abilene, Ks. Street address of well location if in city:				3. Owner of well: Bert & Wetta Industries R.R. or street: Maize, Kansas City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 18 in. Completion date 3/30/77 Well depth 51 ft.		
		<p style="text-align: center;">Well No. 5 (TH 1-77)</p>		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material Steel Height: Above xxxx Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 20.4 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 34.24 lbs./ft. Dia. 10 in. to 41 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 0.307		
Top soil		0	2	10. Screen: Manufacturer's name Layne & Bowler, Inc. Type Stainless Dia. 10" Slot/gauze 0.105" Length 10' Set between 41 ft. and 51 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/8 x 3/8		
Brown clay & silt		2	41	11. Static water level: <input type="checkbox"/> mo./day/yr. 19.0 ft. below land surface Date 3/29/77		
Medium to coarse sand to medium coarse gravel		41	51	12. Pumping level below land surfaces: No Test <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 20 Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.		
				16. Nearest source of possible contamination: Underground ft. 55 Direction SW Type Fuel Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name Wichita, Kansas License No. _____ Address Wichita, Kansas Signed W. P. Hood Date 4/15/77 Authorized representative		
19. Remarks:						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T
R
W
E
21
1/4
1/4
1/4
1/4
S
W
E
N
E