

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County JOHNSON	Fraction SW 1/4 NW 1/4 SW 1/4	Section number 16	Township number T 13	Range number S R 23 EW
2. Distance and direction from nearest town or city: Street address of well location if in city: 2 1/2 NW OLAATHE			3. Owner of well: Thomas Hadd R.R. or street: 1009 Cooper City, state, zip code: Olathe, Kansas 66061			
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		6. Bore hole dia. 7 1/2 in. Completion date 11-76 Well depth 100 ft.	
5. Type and color of material			From	To	7. <input checked="" type="checkbox"/> Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored ___ Reverse rotary	
surface (clay)			0	24	8. Use: <input checked="" type="checkbox"/> Domestic ___ Public supply ___ Industry ___ Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other	
line (grey)			24	34	9. Casing: Material ___ Height: Above or below Threaded ___ Welded ___ Surface 12 in. RMP ___ PVC <input checked="" type="checkbox"/> Weight 1.75 lbs./ft. Dia. 5 in. to 100 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. 1/4 MNC	
shale (dark grey)			34	42	10. Screen: Manufacturer's name RowinTech Type PVC Dia. 5" Slot/Drill/slot length 66' Set between 34 ft. and 100 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/8	
line (grey)			42	49	11. Static water level: ___ mo./day/yr. 36 ft. below land surface Date 11-76	
shale (grey)			49	67	12. Pumping level below land surfaces: ___ ft. after ___ hrs. pumping ___ g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield ___ g.p.m.	
lime (lt. grey)			67	81	13. Water sample submitted: ___ mo./day/yr. <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ___	
shale (green)			81	90	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter ___ Inches above grade	
lime (dark grey)			90	100	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement ___ Bentonite ___ Concrete Depth: From 5 ft. to 34 ft.	
CASING DRILLED AND SLOTTED 34'-100'					16. Nearest source of possible contamination: ft. 75 Direction E Type CREEK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ___ No	
perforation size: 3/32"					17. Pump: ___ Not installed Manufacturer's name Goula's Model number JEH HP 1/2 Volts 230 Length of drop pipe 100 ft. capacity ___ g.p.m. Type: <input checked="" type="checkbox"/> Submersible ___ Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other	
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. E. Young Drilling Co. 240 Business name 6355 ROBIN License No. 240 Address MEARIAN, 240 Signed E.E. YOUNG Date 1-77 Authorized representative	
18. Elevation: 870 867 Topography: <input checked="" type="checkbox"/> Hill ___ Slope ___ Upland ___ Valley		19. Remarks: Customer is aware of State regulation and agrees to install a 4' square re-enforced concrete platform around top of well. Thomas Hadd				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR = 846 * 7 = 834