


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

T R EW sec 1/4 1/4 1/4 No.

Sept 10/16/75

1 Location of well:	County <b>Dickinson</b>	Township name <b>Center</b>	Fraction <b>sWSW SW</b>	Section number <b>21</b>	Town number <b>T 13S</b>	Range number <b>R 3E</b>
Distance and direction from nearest town or city: Street address of well location if in city: <b>304 South Garfield</b>			3 Owner of well: <b>Eddie May</b> Address: <b>304 South Garfield Enterprise, Kansas</b>			
Locate with "X" in section below: N W E S 1 Mile		Sketch map: <b>X Well</b> <b>Sewer Line</b>  <b>CCe</b>		4 Well depth: <b>82</b> ft. Date of completion <b>8/7/75</b> Well diameter <b>8</b> in.		
2 Type and color of material		From To		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Clay		0 9		7 Casing: Material <b>PVC</b> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>18</b> in. Diam. <b>5</b> in. to <b>82</b> ft. depth! Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth!		
Limestone		9 30		8 Screen: Manufacturer <b>Western Plastics</b> Type <b>PVC</b> Dia. <b>5"</b> <b>Slop</b> gauze <b>3/32</b> Length <b>57'</b> Set between <b>25</b> ft. and <b>82</b> ft. Fittings: <b>1/16 to 3/8</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material _____		
Yellow clay		30 35		9 Static water level: <b>30</b> ft. below land surface Date <b>8/7/75</b>		
Rock		35 61		10 Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <b>24</b> g.p.m.		
Red clay		61 80		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Clay rock		80 82		12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
(use a second sheet if needed)				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Mortar <input type="checkbox"/> _____ Depth: From <b>0</b> ft. to <b>10</b> ft.		
16 Remarks: elevation				14 Nearest source of possible contamination: <b>None</b> ft. <b>75</b> Direction <b>S</b> Type <b>Sewer Line</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Reda</b> Model number <b>18919</b> HP <b>3/4</b> Volts <b>220</b> Length of drop pipe <b>75</b> ft. capacity <b>14</b> g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Rader Drilling Co. 194</b> Business name <b>Carlton, Kansas</b> License No. <b>87429</b> Address <b>_____</b> Signed <b>Frank Rader</b> Date <b>8-26-75</b> Authorized representative		