


4850

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Geary	Fraction SE 1/4 NW 1/4 NW 1/4	Section number 32	Township number T 13 S	Range number R 6 E/W
2. Distance and direction from nearest town or city: of Skiddy 1 mile North		3. Owner of well: Tom Ohm		R.R. or street: R 61	
Street address of well location if in city:		City, state, zip code: Burdick			
4. Locate with "X" in section below: N  W E S 1 Mile			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 6 1/4 in. Completion date 2-22-77 Well depth 45 ft.
Topsoil Blk			0	1	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Clay - Brn			1	12	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Clay & Flint Gravel			12	18	9. Casing: Material Pits Height: <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded glu Surface 16 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 18 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 1200
Clay - Yel			18	30	10. Screen: Manufacturer's name Sunflower Type RMP Dia. 5" <input checked="" type="checkbox"/> Slot gauze YB Length 27' Set between 18 ft. and 45 ft. _____ ft. and _____ ft. Gravel pack? NO Size range of material _____
LIME - Broken Yel			30	35	11. Static water level: _____ mo./day/yr. 17 ft. below land surface Date 7-22-77
LIME - Gray			35	45	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1.2 g.p.m.
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
					14. Well head completion: <input type="checkbox"/> Pitless adapter 16 Inches above grade
					15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.
					16. Nearest source of possible contamination: ft. 90 Direction S Type Draw Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Zinn Water Well Drilling 218 Business name _____ License No. _____ Address Post Springs, Kan Signed Joseph A. Zinn Date 7-22-77 Authorized representative
18. Elevation:	19. Remarks: 4'x4'x4" concrete slab to be responsibility of owner. X Carol Ohm				
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T
R
E
W
S
E
1/4
1/4
2/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5