


78 Volland

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

All that part of $S W \frac{1}{4}$ $S W \frac{1}{4}$ of Section 3 Township 13 R
Range 9 east of beginning to a point on east line of said
 $S W \frac{1}{4}$ $S W \frac{1}{4}$ of Section 3, 50 ft thence South, 150 ft thence
east 200 ft to east line of said $S W \frac{1}{4}$ $S W \frac{1}{4}$ of Section 3
thence north 150 ft to place of beginning

WATER WELL RECORD
KSA-879-1201-1215Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Wabaunsee	Fraction $SW \frac{1}{4}$ $SW \frac{1}{4}$ $SW \frac{1}{4}$	Section number 3	Township number T 13 S	Range number R 9 east E/W
2. Distance and direction from nearest town or city: Alma on Highway 1 mi West			3. Owner of well: George Walls R.R. or street: R1 Box 511 City, state, zip code: Alma, Kans 66401		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			6. Bore hole dia. 10 in. Completion date 7-31-79 Well depth 94 ft.		
			7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 94 ft. depth Wall Thickness: 1/2 in. Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 267		
			10. Screen: Manufacturer's name Can-Tek Type PVC Dia. 5 Slot size 0.40 Length 40 Set between 94 ft. and 54 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 X 1/4		
			11. Static water level: 70 ft. below land surface Date 7-31-79 mo./day/yr.		
			12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 30 g.p.m.		
			13. Water sample submitted: 70 ft. below land surface Date 7-31-79 mo./day/yr.		
			14. Well head completion: NA <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> 1-2 With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 16 ft. to 5 ft.		
			16. Nearest source of possible contamination: 100 ft. Direction North Type Septic tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 1202' Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			19. Remarks: prob OK in direction		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Shades Drilling Co. 237 Business name License No. Address Blue Rapids Signed Harold Strader Date 7-31-79 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5