

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

114 ✓

WATER WELL RECORD
KSA 82a-1201-1215

JCC

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

cheryl jd

1. Location of well:		County WABAUNSEE	Fraction SW SW SW SW 1/4 SE 1/4	Section number 4	Township number T # 14 S	Range number R # 11 E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:				3. Owner of well: R.R. or street: City, state, zip code:		
2. Distance and direction from nearest town or city: AT LAKE WABAUNSEE				3. Owner of well: Gene Williams R.R. or street: City, state, zip code: LAKE WABAUNSEE		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>8</u> in. Completion date <u>4-26-76</u> Well depth <u>80</u> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
grey lime		0	20	9. Casing: Material <u>PVC</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in. RMP <u>PVC 9L</u> Weight <u>2.58</u> lbs./ft. Dia. <u>5</u> in. to <u>80</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>80</u> ft. depth gage No. <u>2.58</u>		
grey shale		20	34	10. Screen: Manufacturer's name <u>PUMCO</u> Type <u>PVC</u> Dia. <u>5</u> Slot/gauze <u>.060</u> Length <u>40'</u> Set between <u>30</u> ft. and <u>70</u> ft. ft. and <u>70</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4 X 1/8</u>		
yellow lime		34	36	11. Static water level: <u>35</u> ft. below land surface Date <u>4-26-76</u> mo./day/yr.		
Red shale		36	67	12. Pumping level below land surfaces: <u>AIR TEST</u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>8 gph</u> g.p.m.		
grey lime		67	74	13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date		
grey shale		74	80	14. Well head completion: <u>CAPPED</u> <input type="checkbox"/> Pitless adapter <u>24</u> inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: ft. <u>100</u> Direction <u>W</u> Type <u>SEPTIC</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: <u>305</u> Topography: <u>Pln</u> <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: <u>OWNER WILL INSTALL SLAB</u>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>STRADER DRUG CO INC 182</u> Business name License No. Address <u>ATI HOLTOM, KS</u> Signed <u>Dale Ashum</u> Date <u>4-26-76</u> Authorized representative		

T 11 140 4 SESESE
R
S
1/4 1/4 1/4 1/4