

87

ESKRIDGE

Yjd

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 820-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DDC

1. Location of well: County Wabaunsee Fraction SE SE SW 1/4 SW 1/4 SW 1/4 Section number 30 Township number T 17 S Range number R 12 E

2. Distance and direction from nearest town or city: 4 S .8 W 3. Owner of well: MAX CROSS
Street address of well location if in city: OF ESKRIDGE R.R. or street: RT 1
City, state, zip code: ESKRIDGE

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. 8 in. Completion date 6-2-78
Well depth 80 ft.

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material PVC Height: Abv or below
Threaded Welded Surface 24 in.
RMP PVC 96 Weight 258 lbs./ft.
Dia. 5 in. to 80 ft. depth Wall Thickness: inches or
Dia. in. to ft. depth gage No. 279

5. Type and color of material	From	To
<u>TOP SOIL</u>	<u>0</u>	<u>4</u>
<u>Clay BROWN</u>	<u>4</u>	<u>35</u>
<u>LIMESTONE, BROWN</u>	<u>35</u>	<u>36</u>
<u>Shale, grey</u>	<u>36</u>	<u>80</u>

10. Screen: Manufacturer's name PUMPCO MPI
Type PVC Dia. 5
 Slotted gauze 1020 Length 50
Set between 30 ft. and 80 ft.
 ft. and ft.
Gravel pack? Size range of material 10/20x40/80

11. Static water level: 35 ft. below land surface Date 6-2-78 mo./day/yr.

12. Pumping level below land surfaces:
 ft. after hrs. pumping g.p.m.
 ft. after hrs. pumping g.p.m.
Estimated maximum yield 59 gph g.p.m.

13. Water sample submitted: Yes No Date mo./day/yr.

14. Well head completion: CAP
 Pitless adapter 24 Inches above grade

15. Well grouted?
With: Neat cement Bentonite Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:
ft. 150 Direction E Type SEPTIC
Well disinfected upon completion? Yes No

17. Pump: Not installed
Manufacturer's name
Model number HP Volts
Length of drop pipe ft. capacity g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

18. Elevation: 1348
Topography: RM
 Hill
 Slope
 Upland
 Valley

19. Remarks: OWNER TO INSTAL slab

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
STADER DRIG Co Inc 182
Business name License No.
Address RT 1 Holton, KS
Signed Dale Ashum Date 6-5-78
Authorized representative

174 120
30-Subsided
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5