

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Osage	Fraction 1/4 NW 1/4 SE 1/4	Section number 23	Township number T 14S	Range number R 15E E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
2 1/2 W 1/2 S of Carbondale			Jim Mercer Carbondale, Ks.			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 7 in. Completion date 8-10-76 Well depth 127 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Soil		0	2	9. Casing: Material PITS Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 127 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200		
Clay yellow		2	6	10. Screen: Manufacturer's name Jess & Lowell 200 Type RMP Dia. 5" Slot/gauze 3/16 Length 87' Set between 40 ft. and 127 ft. _____ ft. and _____ ft. Gravel pack? NO Size range of material _____		
Lime hard		6	12	11. Static water level: _____ mo./day/yr. 64 ft. below land surface Date 8-10-76		
shale grey		12	35	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Lime broken		35	40	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
shale grey sticky		40	72	14. Well head completion: <input type="checkbox"/> Pitless adapter 24 inches above grade		
Lime hard		72	80	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 25 ft.		
shale sandy in spots		80	105	16. Nearest source of possible contamination: ft. 400 Direction North Type Lake Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sandstone grey		105	127	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Robison DeLong 3316A Business name _____ License No. _____ Address Perry, Ks Signed Jack Robison Date 8-10-76 Authorized Representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 14 R 15E S 23 Sec 23 NWSE 1/4 1/4