USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Osage	NW 1/4 SW 1/4 NE 1/4	22	T 14 S	R 16E E/W

2. Distance and direction from nearest town or city: 3½E of Carbondale
Street address of well location if in city:

3. Owner of well: James Deylin Jr.
R.R. or street: 215 Kendal
City, state, zip code: Topeka KS 66606

4. Locate with "X" in section below: Sketch map: ⊗ No Home

N, W, E, S; NW, NE, SW, SE; 1 Mile

6. Bore hole dia. 6¾ in. Completion date 8/4/79
Well depth 80 ft.

7. X Cable tool __ Rotary __ Driven __ Dug __ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: X Domestic __ Public supply __ Industry __ Irrigation __ Air conditioning __ Stock __ Lawn __ Oil field water __ Other

9. Casing: Material PVC Height: Above or below Surface 24 in.
Threaded __ Welded __ Weight __ lbs./ft.
RMP X PVC __ Wall Thickness: inches or gage No. 200
Dia. 5 in. to 80 ft. depth
Dia. __ in. to __ ft. depth

5. Type and color of material	From	To
Top Soil	0	3
Sandstone	3	10
Shale	10	14
Br Lime	14	16
Shale	16	40
Lime	40	46
Shale	46	49
Lime	49	59
Shale dark	59	63
Lime	63	65
Shale	65	72
Lime white	72	76
Shale	76	77
Lime	77	80

(Use a second sheet if needed)

10. Screen: Manufacturer's name Sunflower
Type RMP Dia. 5"
Slot/gauze 3/16 Length 65'
Set between 15 ft. and 80 ft.
ft. and ft.
Gravel pack? NO Size range of material

11. Static water level: 14 ft. below land surface Date 8/1/79 mo./day/yr.

12. Pumping level below land surfaces:
ft. after hrs. pumping g.p.m.
ft. after hrs. pumping g.p.m.
Estimated maximum yield 2 g.p.m.

13. Water sample submitted: Yes X No Date mo./day/yr.

14. Well head completion: Pitless adapter 24 Inches above grade

15. Well grouted? yes
With: X Neat cement Bentonite Concrete
Depth: From 0 ft. to 15 ft.

16. Nearest source of possible contamination: ft. 100+ Direction North Type Septic
Well disinfected upon completion? X Yes No

17. Pump: X Not installed
Manufacturer's name
Model number HP Volts
Length of drop pipe ft. capacity g.p.m.
Type: Submersible Turbine Jet Reciprocating Centrifugal Other

18. Elevation: 1050
Topography: X Hill X Slope Upland Valley

19. Remarks: Owner to install slab

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Robison Drilling 316
Business name License No.
Address Perry KS
Signed Jack Robison Authorized representative Date 8/17/79

T 14 R 16 E/W Sec 22 1/4 NW 1/4 SW 1/4 NE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5