

*32

Edgerton

North Port Ch

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Johnson	Fraction NW 1/4 NE 1/4 NE 1/4	Section number 13	Township number T 14 S R	Range number 21 E
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Charles McNevin's R.R. or street: RT 1 BX 58A City, state, zip code: EDGERTON KS 666021			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 7 3/8 in. Completion date 10-15-79 Well depth 120 ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Surface		0	1	9. Casing: Material _____ Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 1.5 lbs./ft. Dia. 5 in. to 120 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. Sch 300		
Clay yellow		1	17	10. Screen: Manufacturer's name Jess & Lowell Type Plastic Dia. 5" Slot/gauze 1/16" Length 100 Set between 20 ft. and 100 ft. Gravel pack? Yes Size range of material 1/4 X 1/2"		
Limestone Brown		17	45	11. Static water level: _____ mo./day/yr. 32 ft. below land surface Date 10-15-79		
Shale Gray		45	48	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 0.36 g.p.m.		
Shale Black		48	54	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Limestone Brown		54	62	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
Shale Dark Gray		62	70	15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 15 ft. to 5 ft.		
Limestone Gray		70	71	16. Nearest source of possible contamination: _____ ft. _____ Direction NW Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Shale Gray		71	73	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Limestone White		73	74			
Sandstone Brown		74	80			
Limestone Gray		80	101			
Shale Gray		101	120			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:			20. Water well contractor's certification:	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		Customer is aware of state regulation to install a 4 ft. square concrete platform around well.			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. F E Young Drilling 240 Business name _____ License No. _____ Address 6355 Robinhood Merriam Signed David Young Date 11-14-79 Authorized representative	

14 210 13
NW NE
Sec