

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <u>Dickinson</u>	Fraction <u>SE 1/4 NW 1/4 SE 1/4</u>	Section number <u>4</u>	Township number T <u>14</u> S R	Range number <u>3</u> <u>EW</u>
2. Distance and direction from nearest town or city <u>2 1/2 South and 3/4 East of Enterprise</u> Street address of well location if in city:			3. Owner of well: <u>Ben Neuschater</u> R.R. or street: <u>Rt Interprise Kan</u> City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			6. Bore hole dia. <u>6 1/4</u> in. Completion date <u>6-18-77</u> Well depth <u>100</u> ft.		
			7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>Pipes</u> Height <u>Above</u> or below Threaded <input type="checkbox"/> Welded <u>glw</u> Surface <u>15</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dio. <u>5</u> in. to <u>80</u> ft. depth Wall Thickness: inches or Dio. _____ in. to _____ ft. depth gage No. <u>1200</u>		
			10. Screen: Manufacturer's name <u>Sunflower</u> Type <u>RMP</u> Dia. <u>5"</u> Slot/gauze <u>Y0</u> Length <u>20'</u> Set between <u>80</u> ft. and <u>100</u> ft. _____ ft. and _____ ft. Gravel pack? <u>NO</u> Size range of material _____		
			11. Static water level: _____ mo./day/yr. <u>63</u> ft. below land surface Date <u>6-18-77</u>		
			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>10</u> g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>15</u> inches above grade		
			15. Well grouted? <u>Yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>3</u> ft. to <u>13</u> ft.		
			16. Nearest source of possible contamination: ft. <u>80</u> Direction <u>N</u> Type <u>Sewer</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			(Use a second sheet if needed)		
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Zinn Water Well Drilling 218</u> Business name _____ License No. _____ Address <u>Lost Springs, Kan</u> Signed <u>Joseph A. Zinn</u> Date <u>7-22-77</u> Authorized representative			

T  
R  
W  
S  
1/4  
1/4  
1/4  
SE  
NWSE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5