


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Franklin	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 23	Township number T 15 S	Range number R 18 E
2. Distance and direction from nearest town or city: Street address of well location if in city:	1 1/2 west / North 1/4 East Centropolis				
3. Owner of well: R.R. or street: City, state, zip code:	Roy E Ramb R1 Ottawa, Kan.				
4. Locate with "X" in section below: Sketch map:	6. Bore hole dia. 6 1/2 in. Completion date 2-16-79 Well depth 155 ft. 9" to 20"				
	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
5. Type and color of material	From	To	9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP 5 PVC <input checked="" type="checkbox"/> Weight shh 40 lbs./ft. Dia. 5 in. to 155 ft. depth Wall Thickness: inches or Dia. 5 in. to 155 ft. depth Gauge No. sch 40		
soil & clay	0	30	10. Screen: Manufacturer's name crown line Type PVC Dia. 5 Slot/gauze 20 3/8 Length 20 Set between 135 ft. and 155 ft. ft. and 155 ft.		
shald	30	132	Gravel pack? no Size range of material		
lime	132	135	11. Static water level: 85 ft. below land surface Date 2-16-79		
I sand	135	155	12. Pumping level below land surfaces: ft. after 3 hrs. pumping 3 g.p.m. ft. after 3 hrs. pumping 3 g.p.m. Estimated maximum yield 3 g.p.m.		
			13. Water sample submitted: no mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3' ft. to 20' ft.		
			16. Nearest source of possible contamination: ft. 100 Direction east Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Royce Swank Model number 371 HP 3 Volts 115 Length of drop pipe 371 ft. capacity 3 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Royce Swank Drilling 371 Business name Royce Swank License No. 371 Address 1111 Ottawa Kansas Signed Royce Swank Date 3-9-79 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5