WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

vK

| | | <u> </u> | 15 A | | | Topeku, Kulisus 00020 |
|--|--------------------------------------|------------------|----------|------------------------------|--------|--|
| 1. Location of well: | County | Fraction NW | | Section r | number | Township number Range number |
| Locuiton of well: | Johnonson N. El/41. 2. 1/4 N. E. 1/4 | | 1/4 | 9 | | T 15 S R 22 E/M |
| 2. Distance and direction from pagest town or city: | | | | ner of well: | | La Vurne Unruk |
| Street address of well location if in city Edgerton, Kansas R.R. or City, str | | | | r street: tate, zip code: | | R.R. |
| 4. Locate with "X" i | | Sketch map: | City, si | rare, zip c | ode: | Garder, Kansas |
| N | | Skerch map: | | | | 6. Bore hole dig. 6 in. Completion date 0-13-17 Well depth 25 ft. |
| ī II | ! 179 | | | | | 7.X Cable tool Rotary Driven Dug |
| NW | NE | | | | | Hollow rod Jetted Bored Reverse rotary |
| w Z | <u> </u> | nause | | | | 8. Use: Z Domestic Public supply Industry |
| ² " | | * | | | | Irrigation Air conditioning Stock Lawn Oil field water Other |
| sw | SE | | | | | 9. Casing: Material PVC Height: Above |
| Thouse Ansertic | | | | | | Threaded Welded Surface in. RMP PVCXXX Weight Sch 40 lbs./ft. |
| S 1 Mile ———————————————————————————————————— | | | | | | Dia. 6 in. to 20 ft. depth Wall Thickness; inches or |
| 5. Type and color of material | | | | From | То | Dia in. to ft. depth gage No. Sch 40 |
| | EHA! | | | | | 10. Screen: Manufacturer's nameNONE |
| | Soil | | | 0 | 8 | Type Dia |
| | Timo | | | 8 | 18 | Slot/gauze Length |
| | Lime | | | | | Set betweenft. andft. |
| | Shale | | | 18 | 20 | Gravel pack 70 Size range of material |
| | T.ime | | | 20 | 28 | 11. Static water level: 20 ft. below land surface Date 10-13-77 |
| | Grey Shale | | | 28 | 30 | 12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. |
| | Red Shale | | | 30 | 32 | ft. after hrs. pumping g.p.m. |
| | INU MATO | | | | | Estimated maximum yield 10 g.p.m. |
| | Grey Shale | | | 32 | 51 | 13. Water sample submitted: mo./day/yr. |
| | Lime | | | 57 | 67 | 14. Well head completion: |
| | Shale | | | 67 | 73 | x Pitless adapter 211 Inches above grade |
| | ОПАТЬ | | | | | 15. Well grouted? |
| | | | | 73 | 75 | With: X Neat sementBentonite Concrete Pentonite Concrete |
| | | | | | | 16. Negrest source of possible contamination: ft. 100 Direction West Type Septic |
| | | | | | | Well disinfected upon completion? XX YesNo |
| | | | | + | | 17. Pump: Not installed |
| | | | | + | • | Manufacturer's name Red Jacket Model number 50N1-98C HP 3 Volts 220 |
| | | | | | | Length of drop pipe 65 ft. capacity 10 g.p.m. |
| | | | | | | Туре: |
| | 7 | | | + | | Submersible Turbine Beciprocating Reciprocating |
| | (Use a second | sheet if needed) | | | | Centrifugal Other |
| 18. Elevation: | 19. Remarks: | | | | | 20. Water well contractor's certification: |
| 993 | | | and a | t the | time | This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. |
| Topography: | there was no co | muamination | | | | WEdgar Swank Drilling 124A |
| —— Hill | | | | | | Business name License No. |
| Slope Slope Upland | | | | | | 12-4-77 |
| Valley | | | | | | Signed Authorized representative |