

To 18015 9-12-78

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Dickinson	Fraction SW 1/4 SW 1/4 SW 1/4	Section number # 35	Township number T 15S	Range number S R 3E	E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:		City of Hope		3. Owner of well: City of Hope R.R. or street: Hope Ks 67451 City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia <u>12</u> in. Completion date <u>8-28-78</u> Well depth <u>80</u> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		EAST WELL		9. Casing: Material <u>pvc</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>20</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. <u>6</u> in. to <u>8</u> ft. depth Wall Thickness: inches or Dia. <u>8</u> in. to <u>80</u> ft. depth gage No. <u>.391+</u>		
				10. Screen: Manufacturer's name <u>ASTM</u> Type <u>pvc</u> Dia. <u>8"</u> Slot/gauze <u>1/8</u> Length <u>20'</u> Set between <u>60</u> ft. and <u>80</u> ft. <u>ft.</u> and <u>1/2 - 3/4"</u> Gravel pack? <input checked="" type="checkbox"/> Size range of material _____		
				11. Static water level: <u>62</u> ft. below land surface Date <u>11-12-77</u> mo./day/yr.		
				12. Pumping level below land surfaces: <u>67</u> ft. after <u>12</u> hrs. pumping <u>65</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>80</u> g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <u>11-15-77</u>		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>3</u> ft. to <u>23</u> ft.		
				16. Nearest source of possible contamination: ft. <u>100</u> Direction <u>SW</u> Type <u>cattle lot</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name <u>Meyers</u> Model number <u>SGK1523</u> HP <u>1/2</u> Volts <u>220</u> Length of drop pipe <u>74</u> ft. capacity <u>50</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Sackhaus Drilling 180</u> Business name <u>Tampa Ks 57483</u> License No. Address <u>Paul Sackhaus</u> Date <u>11-12</u> Signed _____ Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 15
 R 3
 W 0
 Sec 35
 1/4 1/4 1/4
 SWSWSW