

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Morris	Fraction NW 1/4 NE 1/4 NE 1/4	Section number 16	Township number T 15 S R 8 EW	Range number
2. Distance and direction from nearest town or city: 6 mile North & 1 mile West of Council Grove Street address of well location if in city:			3. Owner of well: Leland Scott R.R. or street: RR 1 City, state, zip code: Council Grove, Kan			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 6 1/2 in. Completion date 10-18-77 Well depth 65 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material plb Height Above or below Threaded <input type="checkbox"/> Welded glw Surface 16 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 50 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 1200	
					10. Screen: Manufacturer's name Sunflower Type RMP Dia. 5" Gauge 18 Length 15 Set between 50 ft. and 65 ft. Gravel pack? NO Size range of material _____	
					11. Static water level: _____ mo./day/yr. 40 ft. below land surface Date 10-18-77	
					12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					14. Well head completion: <input type="checkbox"/> Pitless adapter 16 Inches above grade	
					15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 16 ft.	
					16. Nearest source of possible contamination: ft. 1400 Direction E Type Creek Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: _____ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: Windmill - 2 1/2" cylinder <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input checked="" type="checkbox"/> Other	
18. Elevation:		19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Zinn Water Well Drilling 218 Business name _____ License No. _____ Address West Springs, Kan Signed Joseph D. Zinn Date 10-18-77 Authorized representative	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		(Use a second sheet if needed)				

15 - 80W 16 NW NE NE
T R Sec 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5