


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wabaunsee	Fraction SW 1/4 SW 1/4 NE 1/4	Section number 13	Township number T 15 S	Range number R 9 W
2. Distance and direction from nearest town or city: Street address of well location if in city: 6 east- 7 north Council Grove, Ks.				3. Owner of well: Ed Mahoney R.R. or street: RR City, state, zip code: Council Grove Kansas		
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. 8 in. Completion date 6/1/78 Well depth 80 ft.		
5. Type and color of material				From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
top soil black				0	4	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
rock/clay broken yellow				4	15	9. Casing: Material pl Height: 24 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 316 lbs./ft. Dia. 6 in. to 80 ft. depth Wall thickness: inches or Dia. 6 in. to 80 ft. depth gage No. 316
shale grey				15	19	10. Screen: Manufacturer's name shop perf. Type slot Dia. 6 Slot/gauze 3/16 Length 10 ft. Set between 36 ft. and 46 ft. Gravel pack? yes Size range of material 3/8
rock soft yellow				19	26	11. Static water level: 25 ft. below land surface Date 6/1/78
shale green				26	32	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 3 g.p.m.
shale red				32	36	13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____
rock light tan				36	40	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 inches above grade
shale grey				40	47	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.
shale dr. grey				47	53	16. Nearest source of possible contamination: ft. 1500 Direction east Type cattle Well disinfected upon completion? yes Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
rock lt. grey				53	55	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
shale blue/ grey				55	67	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Bledsoe Drilling Co 349 Business name ORP Cottonwood Falls Address John A. Bledsoe Date 6-22-78 Signed John A. Bledsoe Authorized representative
shale dr. grey				67	73	
shale green/ grey				73	80	
(Use a second sheet if needed)						
18. Elevation: 1370 Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: 1370				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5