

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Miami		Fraction SW 1/4 SE 1/4 NW 1/4		Section number 16		Township number T 16S		Range number R 25E E/W			
2. Distance and direction from nearest town or city: 2 1/2 Mile NE of Louis berg, KS.				3. Owner of well: B.W. Cundiff							
Street address of well location if in city:				R.R. or street: RRT 1							
				City, state, zip code: Spring Hill, KS, 66083							
4. Locate with "X" in section below:			Sketch map:			6. Bore hole dia. 6 3/4 in. Completion date 1-26-79			Well depth 200 ft.		
						7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug			<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material			From			To			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry		
Surface			0			7			<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock		
Limestone gray			7			21			<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Shale Brown			21			40			9. Casing: Material Plastic Height: Above or below		
Shale Gray			40			98			Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 14 in.		
Limestone Gray			98			107			RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 1.70 lbs./ft.		
Shale Gray			107			116			Dia. 5 in. to 200 ft. depth Wall Thickness: inches or		
Limestone Light Gray			116			121			Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. sch 200		
Shale Gray			121			138			10. Screen: Manufacturer's name Jess & Lowell		
Limestone Gray			138			144			Type Plastic Dia. 5 1/2		
Shale Greenish Gray			144			182			Slot 1/16" Length 20' Long		
Limestone Gray			182			183			Set between 100 ft. and 120 ft.		
Shale Gray			183			187			160 ft. and 180 ft.		
Limestone			187			200			Gravel pack? yes Size range of material 4' x 1/8"		
Note: Pump to be installed when House completed									11. Static water level: 92 ft. below land surface Date 1-26-79		
									12. Pumping level below land surfaces:		
									____ ft. after ____ hrs. pumping ____ g.p.m.		
									____ ft. after ____ hrs. pumping ____ g.p.m.		
									Estimated maximum yield 1/2 g.p.m.		
									13. Water sample submitted: ____ mo./day/yr.		
									<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
									14. Well head completion:		
									____ Pitless adapter 14 Inches above grade		
									15. Well grouted? yes		
									With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete		
									Depth: From 20 ft. to 5 ft.		
									16. Nearest source of possible contamination:		
									ft. 150' Direction NW Type septic		
									Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
									17. Pump: <input checked="" type="checkbox"/> Not installed yet		
									Manufacturer's name ____		
									Model number ____ HP ____ Volts ____		
									Length of drop pipe ____ ft. capacity ____ g.p.m.		
									Type:		
									<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
									<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
									<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks: Customer is aware of state regulation and agrees to install a 4' square re-enforced concrete platform around top of well.				20. Water well contractor's certification:					
Topography:		x B.W. Cundiff				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.					
<input checked="" type="checkbox"/> Hill						FE Young Drilling 240 Business name License No. Address Merriam, Kansas Signed David Young Date 2-6-79 Authorized representative					
<input checked="" type="checkbox"/> Slope											
<input type="checkbox"/> Upland											
<input type="checkbox"/> Valley											

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T 16 R 25E S 16