


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Morris	Township name Grand View NE 1/4 of NE 1/4	Fraction NE 1/4 of NE 1/4	Section number 30	Town number 16 S	Range number 5 E
Distance and direction from nearest town or city: 2 mile South and 3/4 mile East				3 Owner of well: Milo Waylan Rt. 1 Herington, Kansas		
Locate with "X" in section below: N W E S 1 Mile				Sketch map: 		
2 Type and color of material				From	To	
Top Soil				0	1	
LIME white				1	12	
Shale Yellow				12	15	
Shale Blue				15	18	
LIME				18	20	
Shale Blue				20	23	
LIME				23	27	
Red Rock				27	31	
LIME				31	33	
Red Rock				33	38	
LIME Broken				38	39	
Shale Grey				39	44	
LIME white Water @ 58'				44	58	
LIME Yellow Broken				58	63	
Shale Blue				63	67	
(use a second sheet if needed)						
16 Remarks: elevation Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				4 Well depth: 67 ft. Date of completion 12/16/74 Well diameter 6 in.		
				5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> Water Stock		
				7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 14 in. Diam. 5 in. to 67 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				8 Screen: Perforated with SAW Manufacturer _____ Type _____ Dia. 5" Slot/gauze _____ Length 10' Set between 58 ft. and 67 ft. Fittings: _____ Gravel pack <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material _____		
				9 Static water level: 49 ft. below land surface Date _____		
				10 Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 26 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 14 inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 18 ft.		
				14 Nearest source of possible contamination: ft. 50 Direction North Type Stock Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input checked="" type="checkbox"/> Other		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Zinn Water Well Drilling 218 Business name _____ License No. _____ Address Lost Springs, Kan Signed Joseph A. Zinn Date 12/18/74 Authorized representative		