

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Morris	Fraction SW 1/4 SW 1/4 SW 1/4	Section number E 1/2 of 7	Township number T 16 S R 8	Range number 8
2. Distance and direction from nearest town or city: Street address of well location if in city:				3. Owner of well: R.R. or street: City, state, zip code:		
2. Distance and direction from nearest town or city: 5 West 1 North of Council Grove				J.C. SARRATT 318 N Rockhill Council Grove, Kan		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6 1/2 in. Completion date 1-2-76 Well depth 60 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material RMP Height: Above or below Threaded <input type="checkbox"/> Welded glu Surface 20 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 47 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gauge No. e200		
Flint Gravel Mixed with Top Soil				10. Screen: Manufacturer's name Jess & Lowell Type RMP Dia. 5" Gauge ya Length 13' Set between 47 ft. and 60' ft. Gravel pack? NO Size range of material _____		
LIME - Broken with Flint chert - wht				11. Static water level: _____ mo./day/yr. 18 ft. below land surface Date 1-2-76		
LIME - Solid with Flint - wht				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 15 g.p.m.		
Flint AND LIME wht				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Shale - Lite Blu				14. Well head completion: <input type="checkbox"/> Pitless adapter 20 inches above grade		
Red Rock - Red				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 15 ft.		
Silt - Brn 47' water				16. Nearest source of possible contamination: ft. 50 Direction SW Type Sewage Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Shale - Blu				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Concrete slab to be installed by Customer. He knows this is a regulation J.C. Sarratt		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Zivva Water Well Drilling 218 Business name License No. _____ Address Lost Springs, Kan Signed Joseph A. Zivva Date 1-4-76 Authorized representative		

T 16 S R 8 E
Sec 7
SW 1/4 SW 1/4 SW 1/4