

Sent 6-21-77

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County MOORIS	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 18	Township number T 16-N	Range number S R 8	EW
2. Distance and direction from nearest town or city: 2 MILES WEST OF COUNCIL GROVE THEN NORTH TO FIRST TOWN W		3. Owner of well: LEO DAVIS R.R. or street: City, state, zip code: COUNCIL GROVE KS 66846				
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile						
5. Type and color of material		From	To	6. Bore hole dia. 2 in. Completion date 6-3-77 Well depth 81 ft.		
LIME ROCK YELLOW		0	15	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
LIME ROCK WHITE		15	24	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
LIME ROCK YELLOW		24	30	9. Casing: Material STEEL Height Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 2 1/2 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 24 lbs./ft. Dia. 5 in. to 50 ft. depth; Wall Thickness: inches or Dia. 5 in. to 50 ft. depth; gage No. 1200 MNC		
SHALE BLUE		30	40	10. Screen: Manufacturer's name JESSY LOWELL Type 200 Dia. 5 Slot/gauze SAWBLADE Length Set between 50 ft. and 81 ft. ft. and ft. Gravel pack? <input type="checkbox"/> Size range of material		
SHALE RED		40	45	11. Static water level: 40 ft. below land surface Date 6-3-77 mo./day/yr.		
LIME ROCK GRAY		45	55	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
SHALE BLUE		55	68	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
LIME ROCK GRAY		68	81	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 2 1/2 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> MNC With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.		
				16. Nearest source of possible contamination: ft. 50 Direction WEST Type LIME Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name PUMPCO Model number HP 5 Volts 220 Length of drop pipe 73 ft. capacity g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. A.H. KRAUSE SHOP 156 Business name License No. Address 13 SOUTH BOLFAIST Signed A.H. KRAUSE Date 6-20-77 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		to N				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5