


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Franklin	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 35	Township number T 17 S R 17 E	Range number
2. Distance and direction from nearest town or city: 2W 3N Street address of well location if in city: williamsburg				3. Owner of well Marry thayer R.R. or street: RR City, state, zip code: williamsburg Kan.		
4. Locate with "X" in section below: 				6. Bore hole dia. 6 1/2 in. Completion date 3-24-78 Well depth 220 ft. 9" To 20"		
5. Type and color of material				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <input type="checkbox"/> Height: Above <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 30 lbs./ft. Dia. 6 in. to 20 ft. depth Wall Thickness: inches or Dia. 5 in. to 220 ft. depth gage No. 30640		
				10. Screen: Manufacturer's name CROWN LINE Type PVC Dia. 5 Slot/gauze 1/4 Length 40 Set between 180 ft. and 220 ft. _____ ft. and _____ ft. Gravel pack? NO Size range of material _____		
				11. Static water level: _____ mg./day/yr. 100 ft. below land surface Date 2-21-78		
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 8 ft. to 20 ft.		
				16. Nearest source of possible contamination: ft. NW Direction 60 Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name RED JACKET Model number 75N420 34 Volts 220 Length of drop pipe 210 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				18. Elevation:		
19. Remarks: THIS WELL WAS DRILLED FOR OLD HOUSE				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. EDGAR SWANK 124 Business name 44 OTTAWA KAN License No. _____ Address Edgar Swank Date 4-2-78 Signed _____ Authorized representative		